

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Ecodan Power Inverter 5-170D Packaged	Reg. No.	037-0030-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	Ecodan Power Inverter 5-170D Packaged		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2 kg		
Certification Date	22.06.2020		
Testing basis	HP Keymark scheme rules rev. no. 6		

# Model: PUZ-WM50VHA(-BS) + EHPT17X-\*M\*D

## Configure model

Model name	PUZ-WM50VHA(-BS) + EHPT17X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	1.00 kW	1.62 kW
COP	5.00	3.08

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	183 %	129 %
Prated	5.00 kW	5.00 kW
SCOP	4.66	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.40 kW	4.40 kW
COP Tj = -7°C	3.17	2.04
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.70 kW	2.70 kW
COP Tj = +2°C	4.47	3.23
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	1.90 kW	1.70 kW
COP Tj = +7°C	6.55	4.47
Cdh Tj = +7 °C	0.950	0.960

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	1.80 kW	1.80 kW
COP Tj = 12°C	8.57	6.67
Cdh Tj = +12 °C	0.930	0.940
Pdh Tj = Tbiv	4.40 kW	4.40 kW
COP Tj = Tbiv	3.17	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.19 kW	4.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.84	1.97
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.81 kW	0.81 kW
Annual energy consumption Qhe	2216 kWh	3122 kWh

## Warmer Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	226 %	157 %
Prated	5.00 kW	5.00 kW
SCOP	5.73	4.00
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	5.00 kW	5.00 kW
COP Tj = +2°C	3.70	1.98
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	3.20 kW	3.20 kW
COP Tj = +7°C	5.10	3.40
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	1.90 kW	1.80 kW
COP Tj = 12°C	7.98	5.81
Cdh Tj = +12 °C	0.940	0.950

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.70	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.00 kW	5.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.70	1.98
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1166 kWh	1671 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.84
Heating up time	2:07 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

## Warmer Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	135 %
COP	3.19
Heating up time	2:32 h:min
Standby power input	36.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

## Model: PUZ-WM50VHA(-BS) + ERPT17X-\*M\*D

Configure model	
Model name	PUZ-WM50VHA(-BS) + ERPT17X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	1.00 kW	1.62 kW
COP	5.00	3.08

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate



### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	190 %	133 %
Prated	5.00 kW	5.00 kW
SCOP	4.83	3.40
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.40 kW	4.40 kW
COP Tj = -7°C	3.17	2.04
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.70 kW	2.70 kW
COP Tj = +2°C	4.56	3.29
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	1.90 kW	1.70 kW
COP Tj = +7°C	6.55	4.47
Cdh Tj = +7 °C	0.950	0.960

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	1.80 kW	1.80 kW
COP Tj = 12°C	8.57	6.67
Cdh Tj = +12 °C	0.930	0.940
Pdh Tj = Tbiv	4.40 kW	4.40 kW
COP Tj = Tbiv	3.17	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.19 kW	4.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.84	1.97
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.81 kW	0.81 kW
Annual energy consumption Qhe	2139 kWh	3038 kWh

## Warmer Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	237 %	162 %
Prated	5.00 kW	5.00 kW
SCOP	6.00	4.13
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	5.00 kW	5.00 kW
COP Tj = +2°C	3.70	1.98
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	3.20 kW	3.20 kW
COP Tj = +7°C	4.96	3.35
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	1.90 kW	1.80 kW
COP Tj = 12°C	8.00	5.81
Cdh Tj = +12 °C	0.940	0.950

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.70	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.00 kW	5.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.70	1.98
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1112 kWh	1616 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.84
Heating up time	2:07 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

## Warmer Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	135 %
COP	3.19
Heating up time	2:32 h:min
Standby power input	36.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l