

Page 1 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	Alféa Hybrid Duo gaz Tri 11	Reg. No.	012-022
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT	RISE CERT	
Subtype title	Alféa Hybrid Duo gaz Tri 11		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	20.12.2016		
Testing basis	EN 14511:2013, EN 14825:2013, EN 1	12102:2013	



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: Alféa Hybrid Duo Gaz Tri 11

Configure model		
Model name	Alféa Hybrid Duo Gaz Tri 11	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	9.29 kW
El input	2.62 kW	3.52 kW
СОР	4.12	2.64

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	154 %	112 %
Prated	11.00 kW	9.00 kW
SCOP	3.92	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.70	1.90
Pdh Tj = $+2$ °C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.70
Pdh Tj = $+7^{\circ}$ C	6.20 kW	5.90 kW
COP Tj = +7°C	5.50	3.90
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	7.10	5.20
Pdh Tj = Tbiv	10.00 kW	8.20 kW



Page 4 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = Tbiv	2.70	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW	8.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	80 °C	80 °C
Poff	14 W	14 W
РТО	44 W	32 W
PSB	17 W	17 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Qhe	5930 kWh	6669 kWh



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: Alféa Condensol Hybrid Duo Gaz Tri 11

Configure model		
Model name	Alféa Condensol Hybrid Duo Gaz Tri 11	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	9.29 kW
El input	2.62 kW	3.52 kW
СОР	4.12	2.64

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	46 dB(A)	46 dB(A)		
Sound power level outdoor	68 dB(A)	68 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
η_{s}	154 %	112 %	
Prated	11.00 kW	9.00 kW	
SCOP	3.92	2.87	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	10.00 kW	8.20 kW	
COP Tj = -7°C	2.70	1.90	
Pdh Tj = +2°C	6.10 kW	5.00 kW	
COP Tj = +2°C	3.70	2.70	
Pdh Tj = +7°C	6.20 kW	5.90 kW	
COP Tj = +7°C	5.50	3.90	
Pdh Tj = 12°C	7.40 kW	7.00 kW	
COP Tj = 12°C	7.10	5.20	
Pdh Tj = Tbiv	10.00 kW	8.20 kW	



$$\operatorname{\textit{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = Tbiv	2.70	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW	8.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	80 °C	80 °C
Poff	14 W	14 W
РТО	44 W	32 W
PSB	17 W	17 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Qhe	5930 kWh	6669 kWh