

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	TERRA 6 HPLB	Reg. No.	011-1W0415
Certificate Holder			
Name	Ochsner Wärmepumpen GmbH		
Address	Krackowizerstraße 4	Zip	4020
City	Linz	Country	Austria
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TERRA 6 HPLB		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.4 kg		
Certification Date	30.09.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: TERRA 6 HPLB, AVERAGE CLIMATE

Configure model	
Model name	TERRA 6 HPLB, AVERAGE CLIMATE
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.89 kW	5.26 kW
El input	1.23 kW	1.80 kW
COP	4.80	2.92

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	201 %	137 %
Prated	6.00 kW	5.00 kW
SCOP	5.22	3.63
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.30 kW
COP Tj = -7°C	4.84	3.05
Cdh Tj = -7 °C		
Pdh Tj = +2°C	6.00 kW	5.50 kW
COP Tj = +2°C	5.16	3.58
Cdh Tj = +2 °C		
Pdh Tj = +7°C	6.00 kW	5.70 kW
COP Tj = +7°C	5.48	3.98
Cdh Tj = +7 °C		
Pdh Tj = 12°C	6.10 kW	5.80 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	5.84	4.45
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.90 kW	5.30 kW
COP Tj = Tbiv	4.78	2.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.90 kW	5.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.92
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	55 W	55 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2326 kWh	2990 kWh

Model: TERRA 6 HPLB, low temperature, all climates

Configure model	
Model name	TERRA 6 HPLB, low temperature, all climates
Application	Heating (low temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	5.89 kW
El input	1.23 kW
COP	4.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature
Sound power level indoor	46 dB(A)

EN 14825

	Low temperature
η_s	199 %
Prated	6.00 kW
SCOP	4.90
Tbiv	2 °C
TOL	2 °C
Pdh Tj = +2°C	5.90 kW
COP Tj = +2°C	4.78
Cdh Tj = +2 °C	
Pdh Tj = +7°C	5.90 kW
COP Tj = +7°C	5.09
Cdh Tj = +7 °C	
Pdh Tj = 12°C	6.00 kW
COP Tj = 12°C	5.60
Cdh Tj = +12 °C	
Pdh Tj = Tbiv	5.90 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP $T_j = T_{biv}$	4.78
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.90 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	4.78
WTOL	60 °C
Poff	0 W
PTO	55 W
PSB	10 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Q_{he}	1517 kWh

Colder Climate

EN 12102-1	
	Low temperature
Sound power level indoor	46 dB(A)

EN 14825	
	Low temperature
η_s	207 %
Prated	7.00 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

SCOP	5.11
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	6.00 kW
COP Tj = -7°C	5.33
Cdh Tj = -7 °C	
Pdh Tj = +2°C	6.00 kW
COP Tj = +2°C	5.58
Cdh Tj = +2 °C	
Pdh Tj = +7°C	6.10 kW
COP Tj = +7°C	5.79
Cdh Tj = +7 °C	
Pdh Tj = 12°C	6.10 kW
COP Tj = 12°C	5.52
Cdh Tj = +12 °C	
Pdh Tj = Tbiv	6.00 kW
COP Tj = Tbiv	5.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.22
WTOL	60 °C
Poff	0 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

PTO	55 W
PSB	10 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.44 kW
Annual energy consumption Q _{he}	3362 kWh

Average Climate

EN 12102-1	
	Low temperature
Sound power level indoor	46 dB(A)

EN 14825	
	Low temperature
η_s	201 %
Prated	6.00 kW
SCOP	5.22
T _{biv}	-10 °C
TOL	-10 °C
P _{dh} T _j = -7°C	5.90 kW
COP T _j = -7°C	4.84

This information was generated by the HP KEYMARK database on 22 Jun 2022

Cdh Tj = -7 °C	
Pdh Tj = +2°C	6.00 kW
COP Tj = +2°C	5.16
Cdh Tj = +2 °C	
Pdh Tj = +7°C	6.00 kW
COP Tj = +7°C	5.48
Cdh Tj = +7 °C	
Pdh Tj = 12°C	6.10 kW
COP Tj = 12°C	5.84
Cdh Tj = +12 °C	
Pdh Tj = Tbiv	5.90 kW
COP Tj = Tbiv	4.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78
WTOL	60 °C
Poff	0 W
PTO	55 W
PSB	10 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW

Annual energy consumption Q _{he}	2326 kWh
---	----------