

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	AW-TDF190-H31	Reg. No.	ICIM-PDC-000034
Certificate Holder			
Name	Airwell Residential S.A.S.		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Subtype title	AW-TDF190-H31		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.1 kg		
Certification Date	20.06.2019		

This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: AW-TDF190-H31

Configure model

Model name	AW-TDF190-H31
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	51 dB(A)

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed