

Page 1 of 7

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

١.	^		ıi.	n	
ш	u	ч	ш		

Summary of	Split 120	Reg. No.	011-1W0443
Certificate Holder		'	<u> </u>
Name	Bosch Termotecnologia S.A.		
Address	EN 16 -Km 3.7 - Cacia	Zip	3800-533
City	Aveiro	Country	Portugal
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Split 120		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.55 kg		
Certification Date	29.03.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 8		



# Model: Bosch Compress CS3000DW 120-1 S

Configure model		
Model name	Bosch Compress CS3000DW 120-1 S	
Units	Outdoor	
Climate zone (for heating)	n/a	
Heat Source	Outdoor Air	
Any additional heat sources	n/a	

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	



### Domestic Hot Water (DHW)

### **Average Climate**

EN 16147		
Declared load profile	М	
Efficiency ηDHW	103 %	
СОР	2.39	
Heating up time	2:47 h:min	
Standby power input	31.4 W	
Reference hot water temperature	53.8 °C	
Mixed water at 40°C	185 l	

EN 12102-2	
Sound power level outdoor	61 dB(A)

## Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

# Model: Buderus Logatherm WPTS120.1

Configure model			
Model name	Buderus Logatherm WPTS120.1		
Units	Outdoor		
Climate zone (for heating)	n/a		
Heat Source	Outdoor Air		
Any additional heat sources	n/a		

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	



### Domestic Hot Water (DHW)

### **Average Climate**

EN 16147		
Declared load profile	М	
Efficiency ηDHW	103 %	
СОР	2.39	
Heating up time	2:47 h:min	
Standby power input	31.4 W	
Reference hot water temperature	53.8 °C	
Mixed water at 40°C	185 l	

EN 12102-2	
Sound power level outdoor	61 dB(A)

## Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed



# Model: e.l.m leblanc Ondéa PAC Split 120-1

Configure model		
Model name	e.l.m leblanc Ondéa PAC Split 120-1	
Units	Outdoor	
Climate zone (for heating)	n/a	
Heat Source	Outdoor Air	
Any additional heat sources	n/a	

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	



### Domestic Hot Water (DHW)

## Average Climate

EN 16147		
Declared load profile	М	
Efficiency ηDHW	103 %	
СОР	2.39	
Heating up time	2:47 h:min	
Standby power input	31.4 W	
Reference hot water temperature	53.8 °C	
Mixed water at 40°C	185 l	

EN 12102-2		
Sound power level outdoor	61 dB(A)	

## Operating test

EN 16147		
Temperature operating range	passed	
Safety devices checking test	passed	
Condensate draining	passed	