

$$\operatorname{\textit{Page}}\ 1$$ of 3 This information was generated by the HP KEYMARK database on 22 Jun 2022

١.	$\overline{}$	\sim	ın	
	u	u		

Summary of	AQUA PLUS SWAN-2 300S	Reg. No.	ICIM-PDC-000031	
Certificate Holder		<u> </u>		
Name	Clivet s.p.a.	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032	
City	z.i. Villapaiera - Feltre (BL)	Country	Italy	
Certification Body	ICIM S.p.A.	ICIM S.p.A.		
Subtype title	AQUA PLUS SWAN-2 300S	AQUA PLUS SWAN-2 300S		
Heat Pump Type	Heat Pump for Domestic Hot Wa	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a	R134a		
Mass of Refrigerant	1.5 kg			
Certification Date	02.05.2019			
Testing basis	HP KEYMARK certification scheme rules rev. no. 4			



This information was generated by the HP KEYMARK database on 22 Jun 2022

Model: SWAN-2 300S

Configure model		
Model name	SWAN-2 300S	
Units	Indoor	
Climate zone (for heating)	n/a	
Heat Source	n/a	
Any additional heat sources	n/a	

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	



Domestic Hot Water (DHW)

Average Climate

EN 12102-2		
Sound power level indoor	53 dB(A)	

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	123 %	
СОР	3.01	
Heating up time	7:49 h:min	
Standby power input	30.6 W	
Reference hot water temperature	53.1 °C	
Mixed water at 40°C	354 l	

Operating test

EN 16147		
Temperature operating range	naccod	
Temperature operating range	passed	
Safety devices checking test	passed	
Condensate draining	passed	