

Page 1 of 8

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	FDCW60VNX-A	Reg. No.	012-SC0824-18
Certificate Holder			
Name	Mitsubishi Heavy Industries Air Conditioning Europe		ırope
Address	5 The Square	Zip	UB11 1ET
City	Uxbridge, Middlesex	Country	United Kingdom
Certification Body	RISE CERT	·	
Subtype title	FDCW60VNX-A		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.5 kg	1.5 kg	
Certification Date	21.01.2019		



Model: FDCW60VNX-A + HMA60-S

Configure model		
Model name	FDCW60VNX-A + HMA60-S	
Application	Heating + DHW + low temp	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2		
Low temperature Medium temperature		
Heat output	4.80 kW	3.84 kW
El input	0.93 kW	1.37 kW
СОР	5.14	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	188 %	138 %
Prated	4.80 kW	5.30 kW
SCOP	4.70	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.30 kW	4.70 kW
COP Tj = -7°C	2.60	1.88
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	2.60 kW	2.80 kW
COP Tj = +2°C	4.84	3.59
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	1.70 kW	1.80 kW
COP Tj = +7°C	6.91	4.72
Cdh Tj = +7 °C	0.980	0.990

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = 12°C	2.70 kW	2.70 kW
COP Tj = 12°C	7.72	6.47
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	4.30 kW	4.70 kW
COP Tj = Tbiv	2.60	1.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.20 kW	4.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.77
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	58 °C	58 °C
Poff	7 W	7 W
РТО	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.20 kW
Annual energy consumption Qhe	2089 kWh	3091 kWh

Domestic Hot Water (DHW)

Average Climate





 $$\operatorname{\textit{Page}}\xspace\:5\:\:\text{of}\:8\:$ This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	91 %	
СОР	2.22	
Heating up time	01:40 h:min	
Standby power input	45.0 W	
Reference hot water temperature	51.0 °C	
Mixed water at 40°C	230	



Model: FDCW60VNX-A + HSB60-W

Configure model		
Model name FDCW60VNX-A + HSB60-W		
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional) n/a		

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2			
Low temperature Medium temperature			
Heat output	4.80 kW	3.84 kW	
El input	0.93 kW	1.37 kW	
СОР	5.14	2.81	

EN 14511-4			
Shutting off the heat transfer medium flow	passed		
Complete power supply failure	passed		
Defrost test	passed		
Starting and operating test	passed		

Average Climate



EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	33 dB(A)	33 dB(A)		
Sound power level outdoor	53 dB(A)	53 dB(A)		

EN 14825				
	Low temperature	Medium temperature		
η_{s}	188 %	138 %		
Prated	4.80 kW	5.30 kW		
SCOP	4.70	3.45		
Tbiv	-7 °C	-7 °C		
TOL	-10 °C	-10 °C		
Pdh Tj = -7°C	4.30 kW	4.70 kW		
COP Tj = -7°C	2.60	1.88		
Cdh Tj = -7 °C	0.980	0.990		
Pdh Tj = $+2^{\circ}$ C	2.60 kW	2.80 kW		
COP Tj = +2°C	4.84	3.59		
Cdh Tj = +2 °C	0.980	0.990		
Pdh Tj = +7°C	1.70 kW	1.80 kW		
COP Tj = +7°C	6.91	4.72		
Cdh Tj = +7 °C	0.980	0.990		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 8 of 8 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.70 kW	2.70 kW
COP Tj = 12°C	7.72	6.47
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	4.30 kW	4.70 kW
COP Tj = Tbiv	2.60	1.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.20 kW	4.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.77
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	58 °C	58 °C
Poff	7 W	7 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.20 kW
Annual energy consumption Qhe	2089 kWh	3091 kWh