

$$\operatorname{\textit{Page}}\ 1$$ of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

| Summary of | BoxAir Inverter BA22I | Reg. No. | 037-0063-21 | |
|---------------------|---|----------|----------------|--|
| Certificate Holder | | | | |
| Name | Master Therm tepelna cerpadla s.r.o. | | | |
| Address | Vaclavske namesti 819/43 | Zip | 110 00 | |
| City | Praha | Country | Czech Republic | |
| Certification Body | SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise) | | | |
| Subtype title | BoxAir Inverter BA22I | | | |
| Heat Pump Type | Outdoor Air/Water | | | |
| Refrigerant | R32 | | | |
| Mass Of Refrigerant | 1.3 kg | | | |
| Certification Date | 26.01.2021 | | | |
| Testing basis | HP Keymark scheme rules rev. no. 7 | | | |



This information was generated by the HP KEYMARK database on 27 Jan 2021

Model: BoxAir Inverter BA22I

| General Data | | |
|--------------|-------------|--|
| Power supply | 1x230V 50Hz | |

Heating

| EN 14511-2 | | | |
|------------------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Heat output | 4.91 kW | 4.52 kW | |
| El input | 1.01 kW | 1.49 kW | |
| СОР | 4.84 | 3.05 | |
| Indoor water flow rate | 0.85 m³/h | 0.49 m³/h | |

| EN 14511-4 | | |
|--|--------|--|
| Shutting off the heat transfer medium flow | passed | |
| Complete power supply failure | passed | |
| Defrost test | passed | |
| Starting and operating test | passed | |

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

| EN 12102-1 | | |
|---------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level outdoor | 50 dB(A) | 50 dB(A) |

| | EN 14825 | |
|------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 177 % | 132 % |
| Prated | 4.51 kW | 4.21 kW |
| SCOP | 4.51 | 3.38 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 3.99 kW | 3.72 kW |
| COP Tj = -7°C | 2.74 | 2.04 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = +2°C | 2.31 kW | 2.16 kW |
| COP Tj = +2°C | 4.31 | 3.19 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = +7°C | 1.68 kW | 1.48 kW |
| $COP Tj = +7^{\circ}C$ | 6.44 | 4.89 |
| Cdh | 0.90 | 0.90 |
| Pdh Tj = 12°C | 1.60 kW | 1.51 kW |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

| COP Tj = 12°C | 7.80 | 5.93 |
|---|-------------|-------------|
| Cdh | 0.91 | 0.93 |
| Pdh Tj = Tbiv | 3.99 kW | 3.72 kW |
| COP Tj = Tbiv | 2.73 | 2.04 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 3.68 kW | 3.47 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.61 | 1.90 |
| WTOL | 60 °C | 60 °C |
| Poff | 19 W | 19 W |
| РТО | 19 W | 19 W |
| PSB | 19 W | 19 W |
| PCK | o w | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.83 kW | 0.74 kW |
| Annual energy consumption Qhe | 2068 kWh | 2570 kWh |