

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	ACV Alféa Excellia Tri 11 BS	Reg. No.	012-C700003
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	ACV Alféa Excellia Tri 11 BS		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	19.12.2019		
Testing basis	EN 14511:2013; EN 14825:2013; EN 12102:2013		

Model: ACV Alféa Excellia Tri 11 BS

Configure model	
Model name	ACV Alféa Excellia Tri 11 BS
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	9.29 kW
El input	2.51 kW	3.52 kW
COP	4.30	2.64

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	154 %	112 %
Prated	11.00 kW	9.00 kW
SCOP	3.92	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.70	1.90
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.70
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.50	3.90
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	7.10	5.20
Pdh Tj = Tbiv	10.00 kW	8.20 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.70	1.90
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	9.90 kW	8.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	44 W	32 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Q_{he}	5930 kWh	6669 kWh