

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	VIESSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)	Reg. No.	011-1W0192
Certificate Holder			
Name	Viessmann Faulquemont SAS		
Address	Avenue André Gouy	Zip	F-57380
City	Faulquemont	Country	France
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	VIESSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R1234ze		
Mass of Refrigerant	1.25 kg		
Certification Date	27.02.2020		

Model: VISSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)

Configure model	
Model name	VISSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	Yes

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	50 dB(A)

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	132 %
COP	3.15
Heating up time	9:37 h:min
Standby power input	30.0 W
Reference hot water temperature	54.7 °C
Mixed water at 40°C	344 l

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed