

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	AUAH + AEI1G50EMX	Reg. No.	ICIM-PDC-000021
Certificate Holder			
Name	Argoclima S.p.A		
Address	Via Alfeno Varo, 35	Zip	25020
City	Alfianello (BS)	Country	Italy
Certification Body	ICIM S.p.A.		
Name of testing laboratory	CEIS		
Subtype title	AUAH + AEI1G50EMX		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.3 kg		
Certification Date	21.02.2019		

Model: AUAH + AEI1G50EMX

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.95 kW	4.10 kW
El input	0.97 kW	1.72 kW
COP	4.09	2.39
Indoor water flow rate	0.69 m ³ /h	0.44 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	151 %	111 %
Prated	2.86 kW	3.41 kW
SCOP	3.85	2.84
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	2.53 kW	3.01 kW
COP Tj = -7°C	2.26	1.75
Pdh Tj = +2°C	1.51 kW	1.86 kW
COP Tj = +2°C	3.78	2.78
Pdh Tj = +7°C	1.02 kW	1.13 kW
COP Tj = +7°C	5.30	3.74
Pdh Tj = 12°C	0.93 kW	1.31 kW
COP Tj = 12°C	7.02	5.88
Pdh Tj = Tbiv	2.53 kW	3.01 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.26	1.75
P _{dh} $T_j = TOL$	2.32 kW	2.07 kW
COP $T_j = TOL$	2.02	1.11
C _{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	5 W	5 W
P _{TO}	8 W	8 W
P _{SB}	5 W	5 W
P _{CK}	35 W	35 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.53 kW	1.34 kW
Annual energy consumption Q _{he}	1534 kWh	2479 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	90 %
COP	2.22
Heating up time	5:36 h:min
Standby power input	45.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	364 l