

This information was generated by the HP KEYMARK database on 5 Mar 2021

Summary of	Loria 6004	Reg. No.	012-013
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Loria 6004		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.1 kg		
Certification Date	27.07.2016		

Model: Loria 6004

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	2.58 kW	3.82 kW
El input	0.48 kW	1.41 kW
COP	5.19	2.64

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 5 Mar 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	127 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.70 kW	3.80 kW
COP Tj = -7°C	3.00	2.00
Pdh Tj = +2°C	2.40 kW	2.50 kW
COP Tj = +2°C	4.50	3.20
Pdh Tj = +7°C	2.00 kW	1.40 kW
COP Tj = +7°C	6.40	4.40
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.70	6.50
Pdh Tj = Tbiv	3.70 kW	3.80 kW

This information was generated by the HP KEYMARK database on 5 Mar 2021

COP $T_j = T_{biv}$	3.00	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.40 kW	3.20 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.60
C_{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.80 kW	1.10 kW
Annual energy consumption Q_{he}	1884 kWh	2708 kWh

Model: Loria Duo 6004

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	2.58 kW	3.82 kW
El input	0.48 kW	1.41 kW
COP	5.19	2.64

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 5 Mar 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	127 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.70 kW	3.80 kW
COP Tj = -7°C	3.00	2.00
Pdh Tj = +2°C	2.40 kW	2.50 kW
COP Tj = +2°C	4.50	3.20
Pdh Tj = +7°C	2.00 kW	1.40 kW
COP Tj = +7°C	6.40	4.40
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.70	6.50
Pdh Tj = Tbiv	3.70 kW	3.80 kW

This information was generated by the HP KEYMARK database on 5 Mar 2021

COP $T_j = T_{biv}$	3.00	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.40 kW	3.20 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.60
C_{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.80 kW	1.10 kW
Annual energy consumption Q_{he}	1884 kWh	2708 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.26
Heating up time	1:36 h:min
Standby power input	31.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	243 l

Model: Loria 6004 2C Duo

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	2.58 kW	3.82 kW
El input	0.48 kW	1.41 kW
COP	5.19	2.64

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	127 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.70 kW	3.80 kW
COP Tj = -7°C	3.00	2.00
Pdh Tj = +2°C	2.40 kW	2.50 kW
COP Tj = +2°C	4.50	3.20
Pdh Tj = +7°C	2.00 kW	1.40 kW
COP Tj = +7°C	6.40	4.40
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.70	6.50
Pdh Tj = Tbiv	3.70 kW	3.80 kW

This information was generated by the HP KEYMARK database on 5 Mar 2021

COP $T_j = T_{biv}$	3.00	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.40 kW	3.20 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.60
C_{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.80 kW	1.10 kW
Annual energy consumption Q_{he}	1884 kWh	2708 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.26
Heating up time	1:36 h:min
Standby power input	31.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	243 l

Model: Loria 6004 (LFC)

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	2.58 kW	3.82 kW
El input	0.48 kW	1.41 kW
COP	5.19	2.64

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	127 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.70 kW	3.80 kW
COP Tj = -7°C	3.00	2.00
Pdh Tj = +2°C	2.40 kW	2.50 kW
COP Tj = +2°C	4.50	3.20
Pdh Tj = +7°C	2.00 kW	1.40 kW
COP Tj = +7°C	6.40	4.40
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.70	6.50
Pdh Tj = Tbiv	3.70 kW	3.80 kW

This information was generated by the HP KEYMARK database on 5 Mar 2021

COP $T_j = T_{biv}$	3.00	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.40 kW	3.20 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.60
C_{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.80 kW	1.10 kW
Annual energy consumption Q_{he}	1884 kWh	2708 kWh