

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	08. Yutaki S & S Combi 5.0HP (tri)	Reg. No.	041-K002-08
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	08. Yutaki S & S Combi 5.0HP (tri)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.4 kg		

# Model: RAS-5WHNPE RWM-5.0NE - Heating Only

Configure model	
Model name	RAS-5WHNPE RWM-5.0NE - Heating Only
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	174 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.43	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50
Pdh Tj = Tbiv	12.00 kW	10.25 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.55	1.70
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	12.10 kW	9.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.50	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
P <sub>off</sub>	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption $Q_{he}$	6335 kWh	7088 kWh

# Model: RAS-5WHNPE RWD-5.0NWE-200S - Heating Only

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWE-200S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	174 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.43	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6335 kWh	7088 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	130 %
COP	3.25
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l
Heating up time	1:10 h:min
Standby power input	49.0 W



# Model: RAS-5WHNPE RWD-5.0NWE-260S - Heating Only

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWE-260S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	174 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.43	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6335 kWh	7088 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	134 %
COP	3.35
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l
Heating up time	1:25 h:min
Standby power input	51.0 W

# Model: RAS-5WHNPE RWD-5.0NWE-200S-K - UK- Heating Only

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWE-200S-K - UK- Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	174 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.43	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6335 kWh	7088 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	130 %
COP	3.25
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l
Heating up time	1:10 h:min
Standby power input	49.0 W



# Model: RAS-5WHNPE RWD-5.0NWE-260S-K - UK- Heating Only

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWE-260S-K - UK- Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	174 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.43	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6335 kWh	7088 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	134 %
COP	3.35
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l
Heating up time	1:25 h:min
Standby power input	51.0 W

# Model: RAS-5WHNPE RWD-5.0NWSE-260S - Solar - Heating Only

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWSE-260S - Solar - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	174 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.43	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6335 kWh	7088 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	134 %
COP	3.35
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l
Heating up time	1:25 h:min
Standby power input	51.0 W



# Model: RAS-5WHNPE RWM-5.0NE - with cooling kit

Configure model	
Model name	RAS-5WHNPE RWM-5.0NE - with cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	176 %	134 %
Prated	14.00 kW	12.00 kW
SCOP	4.48	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6265 kWh	7018 kWh

# Model: RAS-5WHNPE RWD-5.0NWE-200S - with cooling kit

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWE-200S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	176 %	134 %
Prated	14.00 kW	12.00 kW
SCOP	4.48	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6265 kWh	7018 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	130 %
COP	3.25
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l
Heating up time	1:10 h:min
Standby power input	49.0 W

# Model: RAS-5WHNPE RWD-5.0NWE-260S - with cooling kit

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWE-260S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80



## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	176 %	134 %
Prated	14.00 kW	12.00 kW
SCOP	4.48	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6265 kWh	7018 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	134 %
COP	3.35
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l
Heating up time	1:25 h:min
Standby power input	51.0 W

# Model: RAS-5WHNPE RWD-5.0NWSE-260S - Solar - with cooling kit

Configure model	
Model name	RAS-5WHNPE RWD-5.0NWSE-260S - Solar - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
COP	4.71	2.80

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	176 %	134 %
Prated	14.00 kW	12.00 kW
SCOP	4.48	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.10 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.60 kW
Annual energy consumption Qhe	6265 kWh	7018 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	134 %
COP	3.35
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l
Heating up time	1:25 h:min
Standby power input	51.0 W