

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC GS 6	Reg. No.	012-SC1212-17
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	CTC GS 6		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	1.9 kg		

## Model: CTC GS 6

### General Data

Power supply	3x400V 50Hz
Off-peak product	No

## Heating

### EN 14511-2

	Medium temperature
Heat output	5.18 kW
El input	1.78 kW
COP	2.91
Indoor water flow rate	0.57 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Medium temperature
Sound power level indoor	41 dB(A)

### EN 14825

	Medium temperature
$\eta_s$	140 %
Prated	6.41 kW
SCOP	3.69
Tbiv	-6 °C
TOL	-10 °C
Pdh Tj = -7°C	5.30 kW
COP Tj = -7°C	3.18
Pdh Tj = +2°C	5.60 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	5.70 kW
COP Tj = +7°C	4.19
Pdh Tj = 12°C	5.80 kW
COP Tj = 12°C	4.62
Pdh Tj = Tbiv	5.37 kW
COP Tj = Tbiv	3.30

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	5.18 kW
COP Tj = TOL	2.91
Cdh	0.99
WTOL	65 °C
Poff	18 W
PTO	106 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.10 kW
Annual energy consumption Qhe	1685 kWh

## Colder Climate

<b>EN 12102-1</b>	
	<b>Medium temperature</b>
Sound power level indoor	41 dB(A)

<b>EN 14825</b>	
	<b>Medium temperature</b>
$\eta_s$	143 %
Prated	6.03 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	3.78
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	5.50 kW
COP Tj = -7°C	3.65
Pdh Tj = +2°C	5.70 kW
COP Tj = +2°C	4.12
Pdh Tj = +7°C	5.80 kW
COP Tj = +7°C	4.47
Pdh Tj = 12°C	5.90 kW
COP Tj = 12°C	4.75
Pdh Tj = Tbiv	5.30 kW
COP Tj = Tbiv	3.18
Pdh Tj = TOL	5.18 kW
COP Tj = TOL	2.91
Cdh	0.99
WTOL	65 °C
Poff	18 W
PTO	3 W
PSB	18 W
PCK	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.90 kW
Annual energy consumption Q <sub>he</sub>	1685 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	100 %
Heating up time	2:14 h:min
Mixed water at 40°C	239 l
COP	2.50
Standby power input	57.0 W
Reference hot water temperature	49.7 °C

### Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	100 %
Heating up time	2:14 h:min
Mixed water at 40°C	239 l
COP	2.50
Standby power input	57.0 W
Reference hot water temperature	49.7 °C