

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	S2125-12	Reg. No.	012-C700115
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	S2125-12		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.8 kg		
Certification Date	30.12.2021		
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017		

## Model: S2125-12 3x400V

Configure model	
Model name	S2125-12 3x400V
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.36 kW	7.91 kW
El input	1.25 kW	2.44 kW
COP	5.10	3.25

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Colder Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	163 %	131 %
Prated	8.40 kW	8.40 kW
SCOP	4.15	3.35
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.04 kW	4.98 kW
COP Tj = -7°C	3.08	2.53
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.11 kW	3.18 kW
COP Tj = +2°C	5.40	4.25
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.24 kW	2.19 kW
COP Tj = +7°C	6.65	5.31
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.47 kW	2.41 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.36	6.06
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.87 kW	6.81 kW
COP Tj = Tbiv	2.61	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.67 kW	5.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	2.70 kW	2.80 kW
Annual energy consumption Qhe	4990 kWh	6189 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.87	6.81
COP Tj = -15°C (if TOL<-20°C)	2.61	2.13
Cdh Tj = -15 °C	1.000	1.000

## Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	195 %	150 %
Prated	6.80 kW	7.60 kW
SCOP	4.96	3.83
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.47 kW	6.73 kW
COP Tj = -7°C	2.86	2.17
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.64 kW	4.18 kW
COP Tj = +2°C	5.03	3.83
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.44 kW	2.68 kW
COP Tj = +7°C	6.49	5.12
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.47 kW	2.40 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.36	5.87
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.63 kW	7.60 kW
COP Tj = Tbiv	2.51	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.63 kW	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.11
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2835 kWh	4102 kWh

## Model: S2125-12 1x230V

Configure model	
Model name	S2125-12 1x230V
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.36 kW	7.91 kW
El input	1.25 kW	2.44 kW
COP	5.10	3.25

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Colder Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	163 %	131 %
Prated	8.40 kW	8.40 kW
SCOP	4.15	3.35
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.04 kW	4.98 kW
COP Tj = -7°C	3.08	2.53
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.11 kW	3.18 kW
COP Tj = +2°C	5.40	4.25
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.24 kW	2.19 kW
COP Tj = +7°C	6.65	5.31
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.47 kW	2.41 kW



This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.36	6.06
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.87 kW	6.81 kW
COP Tj = Tbiv	2.61	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.67 kW	5.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	2.70 kW	2.80 kW
Annual energy consumption Qhe	4990 kWh	6189 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.87	6.81
COP Tj = -15°C (if TOL<-20°C)	2.61	2.13
Cdh Tj = -15 °C	1.000	1.000

## Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	195 %	150 %
Prated	6.80 kW	7.60 kW
SCOP	4.96	3.83
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.47 kW	6.73 kW
COP Tj = -7°C	2.86	2.17
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.64 kW	4.18 kW
COP Tj = +2°C	5.03	3.83
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.44 kW	2.68 kW
COP Tj = +7°C	6.49	5.12
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.47 kW	2.40 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.36	5.87
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.63 kW	7.60 kW
COP Tj = Tbiv	2.51	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.63 kW	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.11
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2835 kWh	4102 kWh