

Page 1 of 7

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	ATLANTIC GEOLIA 13	Reg. No.	012-C700082	
Certificate Holder	Certificate Holder			
Name	Groupe Atlantic	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000	
City	La Roche Sur Yon	Country	France	
Certification Body	RISE CERT	RISE CERT		
Subtype title	ATLANTIC GEOLIA 13			
Heat Pump Type	Brine/Water and Water/Water			
Refrigerant	R410A			
Mass of Refrigerant	1.7 kg			
Certification Date	16.10.2020			
Testing basis	HP Keymark Scheme Rules rev 8			



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: ATLANTIC GEOLIA 13

Configure model		
Model name	ATLANTIC GEOLIA 13	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Brine/Water Heat Pump

Heating

EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
Low temperature Medium temperature			
Heat output	12.63 kW	11.86 kW	
El input	2.91 kW	4.06 kW	
СОР	4.35	2.92	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com




This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	55 dB(A)	55 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	177 %	140 %
Prated	14.00 kW	13.00 kW
SCOP	4.62	3.70
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.60 kW	11.90 kW
COP Tj = -7°C	4.53	3.43
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	12.70 kW	12.20 kW
COP Tj = +2°C	4.70	3.65
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	12.80 kW	12.40 kW
$COP Tj = +7^{\circ}C$	4.86	4.07
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	12.90 kW	12.60 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



COP Tj = 12°C	5.02	4.47
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	12.60 kW	11.90 kW
COP Tj = Tbiv	4.53	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	11.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.86
WTOL	55 °C	55 °C
Poff	2 W	2 W
РТО	90 W	90 W
PSB	3 W	3 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	1.60 kW
Annual energy consumption Qhe	6386 kWh	7546 kWh

Water/Water Heat Pump

CEN heat pump KEYMARK

Heating



EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
Low temperature Medium temperature			
Heat output	16.78 kW	15.59 kW	
El input	2.94 kW	4.68 kW	
СОР	5.70	3.33	

Average Climate

EN 14825			
	Low temperature	Medium temperature	
η_{s}	210 %	164 %	
Prated	18.00 kW	16.00 kW	
SCOP	5.44	4.29	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7° C	16.10 kW	13.90 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 18 Mar 2022

Inis information was genera	ted by the HP KETMAR	RK database on 18 Mar 2022
$COP Tj = -7^{\circ}C$	5.17	3.43
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	16.30 kW	14.70 kW
COP Tj = +2°C	5.50	4.35
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = $+7^{\circ}$ C	16.50 kW	15.20 kW
$COPTj = +7^{\circ}C$	5.81	4.92
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	16.70 kW	15.70 kW
COP Tj = 12°C	6.14	5.51
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	16.10 kW	13.90 kW
COP Tj = Tbiv	5.17	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.10 kW	13.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.11	3.11
WTOL	55 °C	55 °C
Poff	2 W	2 W
РТО	90 W	90 W
PSB	3 W	3 W
РСК	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity



$$\operatorname{\textit{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	2.10 kW	2.10 kW
Annual energy consumption Qhe	6912 kWh	7576 kWh