This information was generated by the HP KEYMARK database on 16 May 2022

Login

| Summary of | ecoAIR EVI 4-20 kW | Reg. No. | 011-1W0196 |
|---|---|---|---|
| Certificate Holder | | | |
| Name | Ecoforest Geotermia S.L. | | |
| Address | Rúa das Pontes, 25 | Zip | 36350 |
| City | Nigrán (Pontevedra) | Country | Spain |
| Certification Body | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH | | |
| Subtype title | ecoAIR EVI 4-20 kW | | |
| Heat Pump Type | Outdoor Air/Water | | |
| Refrigerant | R410A | | |
| Mass of Refrigerant | 3.5 kg | | |
| Certification Date | 06.01.2020 | | |

# Model: ECOAIR EVI 4-20kW

| Configure model | |
|---|---|
| Model name | ECOAIR EVI 4-20kW |
| Application | Heating (medium temp) |
| Units | Indoor + Outdoor |
| Climate Zone | Colder Climate + Warmer Climate |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |

| General Data | |
|---|---|
| Power supply | 1x230V 50Hz |

## Heating

| EN 14511-2 | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Heat output | 9.22 kW | 9.37 kW |
| El input | 1.85 kW | 2.82 kW |
| COP | 4.97 | 3.33 |

| EN 14511-4 | |
|---|---|
| | |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

## Warmer Climate

| EN 12102-1 | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Sound power level indoor | 0 dB(A) | 0 dB(A) |
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

| EN 14825 | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| $\eta_s$ | 207 % | 159 % |
| Prated | 13.70 kW | 15.16 kW |
| SCOP | 5.24 | 4.06 |
| Tbiv | 2 °C | 2 °C |
| TOL | 2 °C | 2 °C |
| Pdh Tj = +2°C | 13.70 kW | 15.16 kW |
| COP Tj = +2°C | 3.11 | 2.42 |
| Cdh Tj = +2 °C | 0.990 | 1.000 |
| Pdh Tj = +7°C | 9.67 kW | 10.03 kW |
| COP Tj = +7°C | 5.11 | 3.78 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 4.57 kW | 4.65 kW |
| COP Tj = 12°C | 6.78 | 5.18 |
| Cdh Tj = +12 °C | 0.960 | 0.970 |

| | | |
|---|---|---|
| Pdh Tj = Tbiv | 13.70 kW | 15.16 kW |
| COP Tj = Tbiv | 3.11 | 2.42 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 13.70 kW | 15.16 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.11 | 2.42 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 1.000 |
| WTOL | 60 °C | 60 °C |
| Poff | 28 W | 25 W |
| PTO | 24 W | 24 W |
| PSB | 24 W | 24 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 3493 kWh | 4994 kWh |

## Colder Climate

| **EN 12102-1** | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Sound power level indoor | 0 dB(A) | 0 dB(A) |
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

| **EN 14825** |
|---|

| | **Low temperature** | **Medium temperature** |
|---|---|---|
| $\eta_s$ | 167 % | 157 % |
| Prated | 12.00 kW | 12.50 kW |
| SCOP | 4.25 | 4.00 |
| Tbiv | -15 °C | -15 °C |
| TOL | -15 °C | -15 °C |
| Pdh Tj = -7°C | 7.19 kW | 7.67 kW |
| COP Tj = -7°C | 4.15 | 3.33 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 4.66 kW | 4.29 kW |
| COP Tj = +2°C | 5.86 | 5.94 |
| Cdh Tj = +2 °C | 0.970 | 0.970 |
| Pdh Tj = +7°C | 4.15 kW | 4.07 kW |
| COP Tj = +7°C | 7.39 | 8.27 |
| Cdh Tj = +7 °C | 0.960 | 0.950 |
| Pdh Tj = 12°C | 4.54 kW | 4.58 kW |
| COP Tj = 12°C | 9.85 | 12.83 |
| Cdh Tj = +12 °C | 0.950 | 0.930 |
| Pdh Tj = Tbiv | 10.21 kW | 10.05 kW |
| COP Tj = Tbiv | 2.63 | 2.15 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 10.21 kW | 10.05 kW |

| | | |
|---|---|---|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.63 | 2.15 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 28 W | 25 W |
| PTO | 24 W | 24 W |
| PSB | 24 W | 24 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 12.00 kW | 12.50 kW |
| Annual energy consumption Qhe | 6963 kWh | 7705 kWh |
| Pdh Tj = -15°C (if TOL<-20°C) | 10.21 | 10.05 |
| COP Tj = -15°C (if TOL<-20°C) | 2.63 | 2.15 |
| Cdh Tj = -15 °C | 0.990 | 0.990 |

## Average Climate

| **EN 12102-1** | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Sound power level indoor | 0 dB(A) | 0 dB(A) |
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

| **EN 14825** |
|---|

| | **Low temperature** | **Medium temperature** |
|---|---|---|
| $\eta_s$ | 180 % | 151 % |
| Prated | 13.23 kW | 13.88 kW |
| SCOP | 4.57 | 3.84 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 12.26 kW | 11.95 kW |
| COP Tj = -7°C | 3.34 | 2.66 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 7.62 kW | 7.85 kW |
| COP Tj = +2°C | 4.79 | 4.06 |
| Cdh Tj = +2 °C | 0.980 | 0.990 |
| Pdh Tj = +7°C | 5.38 kW | 5.32 kW |
| COP Tj = +7°C | 5.14 | 4.16 |
| Cdh Tj = +7 °C | 0.980 | 0.980 |
| Pdh Tj = 12°C | 4.50 kW | 4.56 kW |
| COP Tj = 12°C | 7.57 | 7.09 |
| Cdh Tj = +12 °C | 0.960 | 0.960 |
| Pdh Tj = Tbiv | 13.23 kW | 13.88 kW |
| COP Tj = Tbiv | 2.74 | 2.14 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 13.23 kW | 13.88 kW |

| | | |
|---|---|---|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.74 | 2.14 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 60 °C | 60 °C |
| Poff | 28 W | 25 W |
| PTO | 24 W | 24 W |
| PSB | 24 W | 24 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 5983 kWh | 7465 kWh |

# Model: ECOAIR EVI T 4-20kW

| Configure model | |
|---|---|
| Model name | ECOAIR EVI T 4-20kW |
| Application | Heating (medium temp) |
| Units | Indoor + Outdoor |
| Climate Zone | Colder Climate + Warmer Climate |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |

| General Data | |
|---|---|
| Power supply | 3x400V 50Hz |

## Heating

| EN 14511-2 | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Heat output | 9.22 kW | 9.37 kW |
| El input | 1.85 kW | 2.82 kW |
| COP | 4.97 | 3.33 |

| EN 14511-4 | |
|---|---|
| | |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

## Warmer Climate

| EN 12102-1 | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Sound power level indoor | 0 dB(A) | 0 dB(A) |
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

| EN 14825 | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| $\eta_s$ | 207 % | 159 % |
| Prated | 13.70 kW | 15.16 kW |
| SCOP | 5.24 | 4.06 |
| Tbiv | 2 °C | 2 °C |
| TOL | 2 °C | 2 °C |
| Pdh Tj = +2°C | 13.70 kW | 15.16 kW |
| COP Tj = +2°C | 3.11 | 2.42 |
| Cdh Tj = +2 °C | 0.990 | 1.000 |
| Pdh Tj = +7°C | 9.67 kW | 10.03 kW |
| COP Tj = +7°C | 5.11 | 3.78 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 4.57 kW | 4.65 kW |
| COP Tj = 12°C | 6.78 | 5.18 |
| Cdh Tj = +12 °C | 0.960 | 0.970 |

| | | |
|---|---|---|
| Pdh Tj = Tbiv | 13.70 kW | 15.16 kW |
| COP Tj = Tbiv | 3.11 | 2.42 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 13.70 kW | 15.16 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.11 | 2.42 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 1.000 |
| WTOL | 60 °C | 60 °C |
| Poff | 28 W | 25 W |
| PTO | 24 W | 24 W |
| PSB | 24 W | 24 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 3493 kWh | 4994 kWh |

## Colder Climate

| **EN 12102-1** | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Sound power level indoor | 0 dB(A) | 0 dB(A) |
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

| **EN 14825** |
|---|

| | **Low temperature** | **Medium temperature** |
|---|---|---|
| $\eta_s$ | 167 % | 157 % |
| Prated | 12.00 kW | 12.50 kW |
| SCOP | 4.25 | 4.00 |
| Tbiv | -15 °C | -15 °C |
| TOL | -15 °C | -15 °C |
| Pdh Tj = -7°C | 7.19 kW | 7.67 kW |
| COP Tj = -7°C | 4.15 | 3.33 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 4.66 kW | 4.29 kW |
| COP Tj = +2°C | 5.86 | 5.94 |
| Cdh Tj = +2 °C | 0.970 | 0.970 |
| Pdh Tj = +7°C | 4.15 kW | 4.07 kW |
| COP Tj = +7°C | 7.39 | 8.27 |
| Cdh Tj = +7 °C | 0.960 | 0.950 |
| Pdh Tj = 12°C | 4.54 kW | 4.58 kW |
| COP Tj = 12°C | 9.85 | 12.83 |
| Cdh Tj = +12 °C | 0.950 | 0.930 |
| Pdh Tj = Tbiv | 10.21 kW | 10.05 kW |
| COP Tj = Tbiv | 2.63 | 2.15 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 10.21 kW | 10.05 kW |

| | | |
|---|---|---|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.63 | 2.15 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 28 W | 25 W |
| PTO | 24 W | 24 W |
| PSB | 24 W | 24 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 12.00 kW | 12.50 kW |
| Annual energy consumption Qhe | 6963 kWh | 7705 kWh |
| Pdh Tj = -15°C (if TOL<-20°C) | 10.21 | 10.05 |
| COP Tj = -15°C (if TOL<-20°C) | 2.63 | 2.15 |
| Cdh Tj = -15 °C | 0.990 | 0.990 |

## Average Climate

| **EN 12102-1** | | |
|---|---|---|
| | **Low temperature** | **Medium temperature** |
| Sound power level indoor | 0 dB(A) | 0 dB(A) |
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

| **EN 14825** |
|---|

| | **Low temperature** | **Medium temperature** |
|---|---|---|
| $\eta_s$ | 180 % | 151 % |
| Prated | 13.23 kW | 13.88 kW |
| SCOP | 4.57 | 3.84 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 12.26 kW | 11.95 kW |
| COP Tj = -7°C | 3.34 | 2.66 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 7.62 kW | 7.85 kW |
| COP Tj = +2°C | 4.79 | 4.06 |
| Cdh Tj = +2 °C | 0.980 | 0.990 |
| Pdh Tj = +7°C | 5.38 kW | 5.32 kW |
| COP Tj = +7°C | 5.14 | 4.16 |
| Cdh Tj = +7 °C | 0.980 | 0.980 |
| Pdh Tj = 12°C | 4.50 kW | 4.56 kW |
| COP Tj = 12°C | 7.57 | 7.09 |
| Cdh Tj = +12 °C | 0.960 | 0.960 |
| Pdh Tj = Tbiv | 13.23 kW | 13.88 kW |
| COP Tj = Tbiv | 2.74 | 2.14 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 13.23 kW | 13.88 kW |

| | | |
|---|---|---|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.74 | 2.14 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 60 °C | 60 °C |
| Poff | 28 W | 25 W |
| PTO | 24 W | 24 W |
| PSB | 24 W | 24 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 5983 kWh | 7465 kWh |