

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	ATLANTIC GEOLIA 5	Reg. No.	012-C700079
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	ATLANTIC GEOLIA 5		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R410A		
Mass of Refrigerant	0.9 kg		
Certification Date	16.10.2020		
Testing basis	HP Keymark Scheme Rules rev 8		

Model: ATLANTIC GEOLIA 5

Configure model	
Model name	ATLANTIC GEOLIA 5
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.64 kW	kW
El input	1.43 kW	kW
COP	3.94	

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	56 dB(A)	56 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	155 %	%
Prated	6.00 kW	kW
SCOP	4.07	
Tbiv	-7 °C	°C
TOL	-10 °C	°C
Pdh Tj = -7°C	5.70 kW	kW
COP Tj = -7°C	3.90	
Cdh Tj = -7 °C	0.990	
Pdh Tj = +2°C	5.80 kW	kW
COP Tj = +2°C	4.10	
Cdh Tj = +2 °C	0.990	
Pdh Tj = +7°C	5.70 kW	kW
COP Tj = +7°C	4.30	
Cdh Tj = +7 °C	0.990	
Pdh Tj = 12°C	5.70 kW	kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	4.40	
Cdh Tj = +12 °C	0.990	
Pdh Tj = Tbiv	5.70 kW	kW
COP Tj = Tbiv	3.90	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.90	
WTOL	50 °C	°C
Poff	2 W	W
PTO	9 W	W
PSB	4 W	W
PCK	0 W	W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	kW
Annual energy consumption Qhe	3369 kWh	kWh

Water/Water Heat Pump

Heating

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14511-4

Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	7.14 kW	6.57 kW
El input	1.44 kW	2.01 kW
COP	4.86	3.26

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	211 %	151 %
Prated	8.00 kW	8.00 kW
SCOP	5.48	3.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.40 kW	6.80 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	5.20	3.30
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	7.60 kW	3.90 kW
COP Tj = +2°C	5.50	4.00
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.70 kW	7.10 kW
COP Tj = +7°C	5.80	4.40
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	7.70 kW	7.20 kW
COP Tj = 12°C	6.10	4.90
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	7.40 kW	6.80 kW
COP Tj = Tbiv	5.20	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.30 kW	6.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.00	3.10
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	9 W	9 W
PSB	4 W	4 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	1.10 kW	1.00 kW
Annual energy consumption Q _{he}	3138 kWh	3973 kWh