Login

Summary of	DAIKIN ALTHERMA LT MONOBLOC 11kW	Reg. No.	011-1W0259
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA LT MONOBLOC 11kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.4 kg		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EDLQ011CV3

Configure model	
Model name	EDLQ011CV3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EBLQ011CV3

Configure model	
Model name	EBLQ011CV3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EBLQ011C3V3

Configure model	
Model name	EBLQ011C3V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EBLQ011CW1

Configure model	
Model name	EBLQ011CW1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EBLQ011C3W1

Configure model	
Model name	EBLQ011C3W1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EDLQ011C3V3

Configure model	
Model name	EDLQ011C3V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EDLQ011CW1

Configure model	
Model name	EDLQ011CW1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EDLQ011C3W1

Configure model	
Model name	EDLQ011C3W1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	10.76 kW
El input	2.43 kW	3.97 kW
COP	4.60	2.71

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	156 %	120 %
Prated	11.00 kW	10.00 kW
SCOP	3.98	3.09
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	8.80 kW
COP Tj = -7°C	2.63	1.99
Pdh Tj = +2°C	6.00 kW	5.30 kW
COP Tj = +2°C	4.05	3.24
Pdh Tj = +7°C	5.70 kW	4.50 kW
COP Tj = +7°C	6.77	4.31
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.41
Pdh Tj = Tbiv	9.10 kW	8.80 kW
COP Tj = Tbiv	2.82	1.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	0.90 kW
Annual energy consumption Qhe	5380 kWh	6260 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.