

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	DAIKIN ALTHERMA H ECH2O / ROTEX HPSU MONOBLOC COMPACT 5KW (300L)	Reg. No.	011-1W0268
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	IGE Institut für GebäudeEnergetik		
Subtype title	DAIKIN ALTHERMA H ECH2O / ROTEX HPSU MONOBLOC COMPACT 5KW (300L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.3 kg		

# Model: RBLQ05C2V3 / RKHWMXB300C

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m <sup>3</sup> /h	0.52 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	2.52	1.65
Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	96 %
COP	2.29
Heating up time	1:56 h:min
Reference hot water temperature	48.0 °C
Mixed water at 40°C	155 l
Standby power input	45.0 W

## Model: RBLQ05C2V3 / RKHWMX300C

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m <sup>3</sup> /h	0.52 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	2.52	1.65
Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

## Domestic Hot Water (DHW)

### Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	96 %
COP	2.29
Heating up time	1:56 h:min
Reference hot water temperature	48.0 °C
Mixed water at 40°C	155 l
Standby power input	45.0 W

## Model: EBLQ05C2V3 / EKHWMXB300C

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m <sup>3</sup> /h	0.52 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	2.52	1.65
Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	96 %
COP	2.29
Heating up time	1:56 h:min
Reference hot water temperature	48.0 °C
Mixed water at 40°C	155 l
Standby power input	45.0 W

## Model: EBLQ05C2V3 / EKHWMX300C

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m <sup>3</sup> /h	0.52 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	2.52	1.65
Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

## Domestic Hot Water (DHW)

### Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	96 %
COP	2.29
Heating up time	1:56 h:min
Reference hot water temperature	48.0 °C
Mixed water at 40°C	155 l
Standby power input	45.0 W