

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	Platinum BC Plus Monobloc 12 16 Trif	Reg. No.	ICIM-PDC-000068-00
Certificate Holder			
Name	BAXI Climatización S.L.U		
Address	López de Hoyos 35	Zip	28002
City	Madrid	Country	Spain
Certification Body	ICIM S.p.A.		
Subtype title	Platinum BC Plus Monobloc 12 16 Trif		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.8 kg		
Certification Date	04.05.2020		

Model: Platinum BC Plus Monobloc 12 Trif

Configure model

Model name	Platinum BC Plus Monobloc 12 Trif
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.30 kW	11.90 kW
El input	2.54 kW	4.23 kW
COP	4.84	2.81

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	126 %
Prated	12.00 kW	13.00 kW
SCOP	4.29	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.52 kW	11.29 kW
COP Tj = -7°C	2.88	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	7.31 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.12 kW	4.96 kW
COP Tj = +7°C	5.74	4.25
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.23 kW	2.37 kW
COP Tj = 12°C	5.40	4.94
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.52 kW	11.29 kW
COP Tj = Tbiv	2.88	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.01 kW	11.88 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	15 W	15 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5726 kWh	8164 kWh

Model: Platinum BC Plus Monobloc 16 Trif

Configure model	
Model name	Platinum BC Plus Monobloc 16 Trif
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	16.10 kW
El input	3.63 kW	5.83 kW
COP	4.49	2.76

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	128 %
Prated	16.00 kW	15.00 kW
SCOP	4.30	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	12.90 kW
COP Tj = -7°C	2.72	2.04
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.92 kW	8.25 kW
COP Tj = +2°C	4.17	3.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.64 kW	5.45 kW
COP Tj = +7°C	5.86	4.32
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.47 kW	2.57 kW
COP Tj = 12°C	6.28	5.12
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.15 kW	12.90 kW
COP Tj = Tbiv	2.72	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.93 kW	11.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	41 W	41 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.40 kW
Annual energy consumption Qhe	7687 kWh	9216 kWh