

Page 1 of 3

### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### **Login**

Summary of	VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180	Reg. No.	011-1W0317		
Certificate Holder					
Name	Viessmann Faulquemont SAS				
Address	Avenue André Gouy	Zip	F-57380		
City	Faulquemont	Country	France		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180				
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)				
Refrigerant	R134a				
Mass of Refrigerant	1.15 kg				



This information was generated by the HP KEYMARK database on 18 Mar 2022

# Model: VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180

Configure model				
Model name VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180				
Units	Indoor			
Climate zone (for heating)	n/a			
Heat Source	n/a			
Any additional heat sources	n/a			

General Data		
Power supply	1x230V 50Hz	
Off-peak product	Yes	

## Domestic Hot Water (DHW)

## **Average Climate**

EN 16147				
Declared load profile	L			
Efficiency ηDHW	122 %			
СОР	2.92			
Heating up time	8h34 h:min			
Standby power input	29.0 W			
Reference hot water temperature	52.9 °C			
Mixed water at 40°C	253 I			

EN 12102-2		
Sound power level indoor	54 dB(A)	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 18 Mar 2022