

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	R32 Monobloc 9kW silent	Reg. No.	011-1W0191
Certificate Holder			
Name	LG Electronics Inc.		
Address	84, Wanam-ro, seongsan-gu	Zip	51554
City	Changwon-si	Country	South Korea
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	R32 Monobloc 9kW silent		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.1 kg		
Certification Date	15.11.2019		

Model: HM091MRS U33

Configure model

Model name	HM091MRS U33
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
Phase-out Date	03.02.2024

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	9.00 kW	6.00 kW
El input	1.76 kW	2.14 kW
COP	5.10	2.80

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	130 %
Prated	8.00 kW	8.00 kW
SCOP	4.68	3.33
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	7.60 kW	7.08 kW
COP Tj = -7°C	3.00	2.00
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.50 kW	4.31 kW
COP Tj = +2°C	4.65	3.20
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.60 kW	3.10 kW
COP Tj = +7°C	6.00	4.60
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.00 kW	2.75 kW
COP Tj = 12°C	8.10	6.71
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.00 kW	7.08 kW
COP Tj = Tbiv	2.50	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.00 kW	6.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.70
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	2.00 kW
Annual energy consumption Qhe	3533 kWh	4971 kWh