

Page 1 of 7

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	CTC GSi 8	Reg. No.	012-SC0346-19
Certificate Holder		<u> </u>	
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT	·	
Subtype title	CTC GSi 8		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	2.4 kg	2.4 kg	
Certification Date	05.11.2019		



Model: CTC GSi 8

Configure model		
Model name	CTC GSi 8	
Application	Heating + DHW + low temp	
Units	Indoor	
Climate Zone	Colder Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data			
Power supply 3x400V 50Hz			
Off-peak product	No		
Phase-out Date	25.10.2023		

Heating

EN 14511-2		
Low temperature Medium temperature		
Heat output	6.08 kW	5.24 kW
El input	1.27 kW	1.78 kW
СОР	4.78	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Colder Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	217 %	162 %
Prated	7.00 kW	7.00 kW
SCOP	5.63	4.24
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.18 kW	4.42 kW
COP Tj = -7°C	5.52	4.01
Cdh Tj = -7 °C	0.97	0.98
Pdh Tj = +2°C	2.70 kW	2.33 kW
COP Tj = +2°C	6.11	4.59
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	2.64 kW	2.35 kW
COP Tj = +7°C	6.14	5.15
Cdh Tj = +7 °C	0.95	0.95
Pdh Tj = 12°C	2.64 kW	2.68 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	6.14	5.92
Cdh Tj = +12 °C	0.95	0.95
Pdh Tj = Tbiv	7.32 kW	6.94 kW
COP Tj = Tbiv	4.56	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.32 kW	6.87 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.56	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
РТО	23 W	23 W
PSB	o w	o w
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3063 kWh	4065 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825





This information was generated by the HP KEYMARK database on 21 Jun 2022

	Low temperature	Medium temperature
η_{s}	208 %	159 %
Prated	7.00 kW	7.00 kW
SCOP	5.39	4.17
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.02 kW	6.58 kW
COP Tj = -7°C	4.75	3.02
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	3.61 kW	4.31 kW
COP Tj = +2°C	5.68	4.71
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	2.47 kW	2.30 kW
COP Tj = +7°C	5.97	4.46
Cdh Tj = +7 °C	0.94	0.94
Pdh Tj = 12°C	2.58 kW	2.28 kW
COP Tj = 12°C	6.05	4.86
Cdh Tj = +12 °C	0.95	0.95
Pdh Tj = Tbiv	7.32 kW	6.91 kW
COP Tj = Tbiv	4.56	2.66

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.32 kW	6.87 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.56	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2683 kWh	3467 kWh

Domestic Hot Water (DHW)

Colder Climate



EN 16147	
Declared load profile	XL
Efficiency ηDHW	98 %
СОР	2.39
Heating up time	01:58 h:min
Standby power input	79.8 W
Reference hot water temperature	49.8 °C
Mixed water at 40°C	239 I

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	98 %
COP	2.39
Heating up time	01:58 h:min
Standby power input	79.8 W
Reference hot water temperature	49.8 °C
Mixed water at 40°C	239