

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Sherpa S2 12T/14T/16T	Reg. No.	ICIM-PDC-000129-00
Certificate Holder			
Name	Olimpia Splendid S.p.A.		
Address	Via Industriale, 1/3	Zip	25060
City	Cellatica (BS)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	Sherpa S2 12T/14T/16T		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.2 kg		
Certification Date	10.12.2021		
Testing basis	Heat Pump KEYMARK rev9		

Model: Sherpa S2 12T

Configure model	
Model name	Sherpa S2 12T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	10.89 kW
El input	2.67 kW	3.87 kW
COP	4.53	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	128 %
Prated	12.17 kW	12.00 kW
SCOP	4.67	3.29
Tbiv	-10 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.01 kW	11.07 kW
COP Tj = -7°C	2.78	1.98
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.68 kW	6.78 kW
COP Tj = +2°C	4.41	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.43 kW	4.21 kW
COP Tj = +7°C	6.55	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.08 kW	3.52 kW
COP Tj = 12°C	9.47	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.17 kW	11.54 kW
COP Tj = Tbiv	2.53	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.17 kW	11.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.64 kW
Annual energy consumption Qhe	5383 kWh	7537 kWh

Model: Sherpa S2 14T

Configure model	
Model name	Sherpa S2 14T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	12.99 kW
El input	3.25 kW	4.50 kW
COP	4.31	2.89

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	130 %
Prated	14.11 kW	13.96 kW
SCOP	4.55	3.32
Tbiv	-9 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.09 kW	12.35 kW
COP Tj = -7°C	2.76	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.98 kW	7.54 kW
COP Tj = +2°C	4.32	3.09
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.06 kW	5.03 kW
COP Tj = +7°C	6.21	4.71
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.72 kW	3.42 kW
COP Tj = 12°C	8.61	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.56 kW	12.35 kW
COP Tj = Tbiv	2.59	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.24 kW	11.47 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.87 kW	2.49 kW
Annual energy consumption Qhe	6405 kWh	8689 kWh

Model: Sherpa S2 16T

Configure model	
Model name	Sherpa S2 16T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.50 kW	14.33 kW
El input	3.70 kW	5.04 kW
COP	4.19	2.84

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	130 %
Prated	15.70 kW	14.96 kW
SCOP	4.37	3.32
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.89 kW	13.17 kW
COP Tj = -7°C	2.65	2.04
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.17 kW	8.40 kW
COP Tj = +2°C	4.16	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.58 kW	5.35 kW
COP Tj = +7°C	6.11	4.74
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.77 kW	3.60 kW
COP Tj = 12°C	7.95	7.04
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.89 kW	12.66 kW
COP Tj = Tbiv	2.65	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.06 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	3.66 kW
Annual energy consumption Qhe	7421 kWh	9312 kWh

Model: Sherpa Aquadue S2 12T

Configure model	
Model name	Sherpa Aquadue S2 12T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	10.89 kW
El input	2.67 kW	3.87 kW
COP	4.53	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	128 %
Prated	12.17 kW	12.00 kW
SCOP	4.67	3.29
Tbiv	-10 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.01 kW	11.07 kW
COP Tj = -7°C	2.78	1.98
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.68 kW	6.78 kW
COP Tj = +2°C	4.41	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.43 kW	4.21 kW
COP Tj = +7°C	6.55	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.08 kW	3.52 kW
COP Tj = 12°C	9.47	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.17 kW	11.54 kW
COP Tj = Tbiv	2.53	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.17 kW	11.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.64 kW
Annual energy consumption Qhe	5383 kWh	7537 kWh

Model: Sherpa Aquadue S2 14T

Configure model	
Model name	Sherpa Aquadue S2 14T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	12.99 kW
El input	3.25 kW	4.50 kW
COP	4.31	2.89

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	130 %
Prated	14.11 kW	13.96 kW
SCOP	4.55	3.32
Tbiv	-9 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.09 kW	12.35 kW
COP Tj = -7°C	2.76	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.98 kW	7.54 kW
COP Tj = +2°C	4.32	3.09
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.06 kW	5.03 kW
COP Tj = +7°C	6.21	4.71
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.72 kW	3.42 kW
COP Tj = 12°C	8.61	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.56 kW	12.35 kW
COP Tj = Tbiv	2.59	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.24 kW	11.47 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.87 kW	2.49 kW
Annual energy consumption Qhe	6405 kWh	8689 kWh

Model: Sherpa Aquadue S2 16T

Configure model	
Model name	Sherpa Aquadue S2 16T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.50 kW	14.33 kW
El input	3.70 kW	5.04 kW
COP	4.19	2.84

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	130 %
Prated	15.70 kW	14.96 kW
SCOP	4.37	3.32
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.89 kW	13.17 kW
COP Tj = -7°C	2.65	2.04
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.17 kW	8.40 kW
COP Tj = +2°C	4.16	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.58 kW	5.35 kW
COP Tj = +7°C	6.11	4.74
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.77 kW	3.60 kW
COP Tj = 12°C	7.95	7.04
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.89 kW	12.66 kW
COP Tj = Tbiv	2.65	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.06 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	3.66 kW
Annual energy consumption Qhe	7421 kWh	9312 kWh

Model: Sherpa Tower S2 12T

Configure model	
Model name	Sherpa Tower S2 12T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	10.89 kW
El input	2.67 kW	3.87 kW
COP	4.53	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	128 %
Prated	12.17 kW	12.00 kW
SCOP	4.67	3.29
Tbiv	-10 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.01 kW	11.07 kW
COP Tj = -7°C	2.78	1.98
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.68 kW	6.78 kW
COP Tj = +2°C	4.41	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.43 kW	4.21 kW
COP Tj = +7°C	6.55	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.08 kW	3.52 kW
COP Tj = 12°C	9.47	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.17 kW	11.54 kW
COP Tj = Tbiv	2.53	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.17 kW	11.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.64 kW
Annual energy consumption Qhe	5383 kWh	7537 kWh

Model: Sherpa Tower S2 16T

Configure model	
Model name	Sherpa Tower S2 16T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.50 kW	14.33 kW
El input	3.70 kW	5.04 kW
COP	4.19	2.84

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	130 %
Prated	15.70 kW	14.96 kW
SCOP	4.37	3.32
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.89 kW	13.17 kW
COP Tj = -7°C	2.65	2.04
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.17 kW	8.40 kW
COP Tj = +2°C	4.16	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.58 kW	5.35 kW
COP Tj = +7°C	6.11	4.74
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.77 kW	3.60 kW
COP Tj = 12°C	7.95	7.04
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.89 kW	12.66 kW
COP Tj = Tbiv	2.65	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.06 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	3.66 kW
Annual energy consumption Qhe	7421 kWh	9312 kWh

Model: Sherpa Tower S2 14T

Configure model	
Model name	Sherpa Tower S2 14T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	10.89 kW
El input	2.67 kW	3.87 kW
COP	4.53	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	128 %
Prated	12.17 kW	12.00 kW
SCOP	4.67	3.29
Tbiv	-10 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.01 kW	11.07 kW
COP Tj = -7°C	2.78	1.98
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.68 kW	6.78 kW
COP Tj = +2°C	4.41	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.43 kW	4.21 kW
COP Tj = +7°C	6.55	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.08 kW	3.52 kW
COP Tj = 12°C	9.47	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.17 kW	11.54 kW
COP Tj = Tbiv	2.53	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.17 kW	11.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.64 kW
Annual energy consumption Qhe	5383 kWh	7537 kWh

Model: Sherpa Aquadue Tower S2 12T

Configure model	
Model name	Sherpa Aquadue Tower S2 12T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	12.99 kW
El input	3.25 kW	4.50 kW
COP	4.31	2.89

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	130 %
Prated	14.11 kW	13.96 kW
SCOP	4.55	3.32
Tbiv	-9 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.09 kW	12.35 kW
COP Tj = -7°C	2.76	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.96 kW	7.54 kW
COP Tj = +2°C	4.32	3.09
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.06 kW	5.03 kW
COP Tj = +7°C	6.21	4.71
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.72 kW	3.42 kW
COP Tj = 12°C	8.61	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.56 kW	12.35 kW
COP Tj = Tbiv	2.59	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.24 kW	11.47 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.87 kW	2.49 kW
Annual energy consumption Qhe	6405 kWh	8689 kWh

Model: Sherpa Aquadue Tower S2 14T

Configure model	
Model name	Sherpa Aquadue Tower S2 14T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	10.89 kW
El input	2.67 kW	3.87 kW
COP	4.53	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	128 %
Prated	12.17 kW	12.00 kW
SCOP	4.67	3.29
Tbiv	-10 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.01 kW	11.07 kW
COP Tj = -7°C	2.78	1.98
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.68 kW	6.78 kW
COP Tj = +2°C	4.41	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.43 kW	4.21 kW
COP Tj = +7°C	6.55	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.08 kW	3.52 kW
COP Tj = 12°C	9.47	6.72
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.17 kW	11.54 kW
COP Tj = Tbiv	2.53	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.17 kW	11.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.64 kW
Annual energy consumption Qhe	5383 kWh	7537 kWh

Model: Sherpa Aquadue Tower S2 16T

Configure model	
Model name	Sherpa Aquadue Tower S2 16T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.50 kW	14.33 kW
El input	3.70 kW	5.04 kW
COP	4.19	2.84

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	130 %
Prated	15.70 kW	14.96 kW
SCOP	4.37	3.32
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.89 kW	13.17 kW
COP Tj = -7°C	2.65	2.04
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.17 kW	8.40 kW
COP Tj = +2°C	4.16	3.11
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.58 kW	5.35 kW
COP Tj = +7°C	6.11	4.74
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.77 kW	3.60 kW
COP Tj = 12°C	7.95	7.04
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	13.89 kW	12.66 kW
COP Tj = Tbiv	2.65	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.06 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	63 W	63 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	3.66 kW
Annual energy consumption Qhe	7421 kWh	9312 kWh