

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Compak KHP 15/190 ACS1	Reg. No.	041-K009-04
Certificate Holder			
Name	Frigicoll		
Address	Blasco de Garay, 4 6	Zip	08960
City	Sant Just Desvern	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	Compak KHP 15/190 ACS1		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.1 kg		
Certification Date	30.04.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 08		

Model: Compak KHP 15/190 ACS1

Configure model	
Model name	Compak KHP 15/190 ACS1
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

Average Climate

EN 12102-2	
Sound power level indoor	58 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.55
Heating up time	7:05 h:min
Standby power input	20.8 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	234 l