

#### Page 1 of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	WWC 160 H/X	Reg. No.	041-K001-33
Certificate Holder			
Name	ait-deutschland Gm	nbH	
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	WPZ		
Subtype title	WWC 160 H/X		
Heat Pump Type	Water/Water		
Refrigerant	R407c		
Mass Of Refrigerant	3.95 kg		
Certification Date	06.09.2019		



This information was generated by the HP KEYMARK database on 17 Dec 2020

# Model: WWC 160H/X

General Data		
Power supply	3x400V 50Hz	

# Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	14.60 kW	13.42 kW	
El input	2.73 kW	3.90 kW	
СОР	5.35	3.44	
Indoor water flow rate	3.00 m³/h	3.00 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Starting and operating test	passed	

## **Average Climate**

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)





#### This information was generated by the HP KEYMARK database on 17 Dec 2020

#### EN 14825

	Low temperature	Medium temperature
$\eta_{s}$	221 %	167 %
Prated	14.60 kW	13.83 kW
SCOP	5.72	4.37
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.61 kW	13.53 kW
COP Tj = -7°C	5.39	3.61
Cdh	1.00	1.00
Pdh Tj = +2°C	14.71 kW	13.97 kW
COP Tj = +2°C	5.70	4.28
Cdh	1.00	1.00
Pdh Tj = +7°C	14.79 kW	14.50 kW
COP Tj = +7°C	5.97	4.92
Cdh	1.00	1.00
Pdh Tj = 12°C	14.87 kW	14.72 kW
COP Tj = 12°C	6.31	5.60
Cdh	1.00	1.00
Pdh Tj = Tbiv	14.60 kW	13.35 kW
COP Tj = Tbiv	5.35	3.40

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	14.60 kW	13.35 kW
COP Tj = TOL	5.35	3.40
WTOL	65 °C	65 °C
Poff	7 W	7 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5278 kWh	6534 kWh

### Warmer Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	240 %	168 %
Prated	14.70 kW	13.83 kW
SCOP	6.19	4.40
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	14.70 kW	13.83 kW
COP Tj = +2°C	5.65	3.41



KEYMARK This info	rmation was generated by the HP	Page 5 KEYMARK database on 17 Dec 2
Cdh	n/a	1.00
Pdh Tj = +7°C	14.79 kW	14.14 kW
COP Tj = +7°C	6.05	3.99
Cdh	1.00	1.00
Pdh Tj = 12°C	14.93 kW	14.58 kW
COP Tj = 12°C	6.68	5.14
Cdh	1.00	1.00
Pdh Tj = Tbiv	14.70 kW	13.83 kW
COP Tj = Tbiv	5.65	3.41
Pdh Tj = TOL	14.70 kW	13.83 kW
COP Tj = TOL	5.65	3.41
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	o w

## Colder Climate

Supplementary Heater: PSUP

Annual energy consumption Qhe

Supplementary Heater: Type of energy input

electricity

0.00 kW

3172 kWh

electricity

0.00 kW

4197 kWh





# $$\operatorname{\textit{Page}}\xspace$ 6 of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

#### EN 14825

	Low temperature	Medium temperature
$\eta_{s}$	246 %	172 %
Prated	14.70 kW	13.83 kW
SCOP	6.34	4.50
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	14.83 kW	14.22 kW
COP Tj = -7°C	6.21	4.16
Cdh	1.00	1.00
Pdh Tj = +2°C	14.91 kW	14.47 kW
COP Tj = +2°C	6.57	4.80
Cdh	1.00	1.00
Pdh Tj = +7°C	14.97 kW	14.65 kW
COP Tj = +7°C	6.84	5.39
Cdh	1.00	1.00
Pdh Tj = 12°C	14.98 kW	14.79 kW
COP Tj = 12°C	6.76	5.84
Cdh	1.00	1.00
Pdh Tj = Tbiv	14.70 kW	13.83 kW
COP Tj = Tbiv	5.65	3.41

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\ 7$$  of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	14.70 kW	13.83 kW
COP Tj = TOL	5.65	3.41
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5716 kWh	7568 kWh
Pdh Tj = -15°C (if TOL<-20°C)	0.01	0.01
COP Tj = -15°C (if TOL<-20°C)	0.01	0.01
Cdh	1.00	1.00