

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	LW 101	Reg. No.	041-K001-36
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LW 101		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	4.8 kg		
Certification Date	08.10.2019		

Model: LW 101

Configure model	
Model name	LW 101
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.40 kW	10.27 kW
El input	2.49 kW	3.71 kW
COP	4.18	2.64

Average Climate

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	Low temperature	Medium temperature
η_s	149 %	121 %
Prated	9.90 kW	9.35 kW
SCOP	3.81	3.11
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.53 kW	6.98 kW
COP Tj = -7°C	2.97	2.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	9.54 kW	9.41 kW
COP Tj = +2°C	3.78	3.11
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.43 kW	10.40 kW
COP Tj = +7°C	4.69	4.04
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.19 kW	12.17 kW
COP Tj = 12°C	5.15	5.02
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.00 kW	7.55 kW
COP Tj = Tbiv	3.19	2.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.84 kW	6.27 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.79
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.06 kW	3.08 kW
Annual energy consumption Qhe	5367 kWh	6216 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	179 %	145 %
Prated	11.53 kW	11.30 kW
SCOP	4.56	3.71
Tbiv	4 °C	4 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

TOL	2 °C	2 °C
Pdh Tj = +2°C	9.50 kW	9.23 kW
COP Tj = +2°C	3.56	2.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.42 kW	10.33 kW
COP Tj = +7°C	4.46	3.27
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.17 kW	12.10 kW
COP Tj = 12°C	5.08	4.61
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.88 kW	9.68 kW
COP Tj = Tbiv	3.94	2.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.50 kW	9.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.56	2.52
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.03 kW	2.07 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q _{he}	3376 kWh	4069 kWh
---	----------	----------

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	132 %	108 %
Prated	8.82 kW	8.22 kW
SCOP	3.38	2.77
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	7.62 kW	7.23 kW
COP T _j = -7°C	3.18	2.37
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	9.57 kW	9.48 kW
COP T _j = +2°C	3.92	3.40
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	10.44 kW	10.42 kW
COP T _j = +7°C	4.83	4.44
C _{dh} T _j = +7 °C	1.00	1.00
P _{dh} T _j = 12°C	12.18 kW	12.20 kW
COP T _j = 12°C	5.00	5.18

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.50 kW	6.06 kW
COP Tj = Tbiv	2.77	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.66 kW	4.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.99	1.34
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.82 kW	8.22 kW
Annual energy consumption Qhe	6437 kWh	7306 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.80	5.37
COP Tj = -15°C (if TOL<-20°C)	2.47	1.72
Cdh Tj = -15 °C	1.00	1.00

Model: LW 101A

Configure model	
Model name	LW 101A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.40 kW	10.27 kW
El input	2.49 kW	3.71 kW
COP	4.18	2.64

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	121 %
Prated	9.90 kW	9.35 kW
SCOP	3.81	3.11
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.53 kW	6.98 kW
COP Tj = -7°C	2.97	2.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	9.54 kW	9.41 kW
COP Tj = +2°C	3.78	3.11
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.43 kW	10.40 kW
COP Tj = +7°C	4.69	4.04
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	12.19 kW	12.17 kW
COP Tj = 12°C	5.15	5.02
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.00 kW	7.55 kW
COP Tj = Tbiv	3.19	2.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.84 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.79
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.06 kW	3.08 kW
Annual energy consumption Qhe	5367 kWh	6216 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	179 %	145 %
Prated	11.53 kW	11.30 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.56	3.71
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	9.50 kW	9.23 kW
COP Tj = +2°C	3.56	2.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.42 kW	10.33 kW
COP Tj = +7°C	4.46	3.27
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.17 kW	12.10 kW
COP Tj = 12°C	5.08	4.61
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.88 kW	9.68 kW
COP Tj = Tbiv	3.94	2.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.50 kW	9.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.56	2.52
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.03 kW	2.07 kW
Annual energy consumption Q _{he}	3376 kWh	4069 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	132 %	108 %
Prated	8.82 kW	8.22 kW
SCOP	3.38	2.77
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	7.62 kW	7.23 kW
COP T _j = -7°C	3.18	2.37
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	9.57 kW	9.48 kW
COP T _j = +2°C	3.92	3.40
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	10.44 kW	10.42 kW
COP T _j = +7°C	4.83	4.44
C _{dh} T _j = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	12.18 kW	12.20 kW
COP Tj = 12°C	5.00	5.18
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.50 kW	6.06 kW
COP Tj = Tbiv	2.77	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.66 kW	4.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.99	1.34
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.82 kW	8.22 kW
Annual energy consumption Qhe	6437 kWh	7306 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.80	5.37
COP Tj = -15°C (if TOL<-20°C)	2.47	1.72
Cdh Tj = -15 °C	1.00	1.00