

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	BoxAir Inverter BA37IS-1	Reg. No.	037-0070-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA37IS-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.5 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		

Model: BoxAir Inverter BA37IS-1

Configure model	
Model name	BoxAir Inverter BA37IS-1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.46 kW	10.34 kW
El input	2.43 kW	3.37 kW
COP	4.71	3.07

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	137 %
Prated	10.93 kW	10.02 kW
SCOP	4.49	3.51
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.67 kW	8.86 kW
COP Tj = -7°C	2.64	2.00
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.10 kW	5.45 kW
COP Tj = +2°C	4.38	3.41
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.06 kW	3.48 kW
COP Tj = +7°C	6.19	4.94
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.75 kW	4.08 kW
COP Tj = 12°C	7.62	6.01
Cdh Tj = +12 °C	0.97	0.97
Pdh Tj = Tbiv	9.67 kW	8.86 kW
COP Tj = Tbiv	2.64	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.04 kW	8.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.85
WTOL	60 °C	60 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.89 kW	1.80 kW
Annual energy consumption Qhe	5029 kWh	5905 kWh