

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Jäspi Inverter Nordic 20	Reg. No.	012-SC0656-18
Certificate Holder			
Name	Kaukora		
Address	Tuotekatu 11	Zip	FI-21200
City	Raisio	Country	Finland
Certification Body	RISE CERT		
Subtype title	Jäspi Inverter Nordic 20		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3 kg		
Certification Date	05.05.2020		

Model: Jäspi Inverter Nordic 20

Configure model	
Model name	Jäspi Inverter Nordic 20
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.94 kW	7.25 kW
El input	1.43 kW	2.35 kW
COP	4.85	3.08

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	199 %	153 %
Prated	11.00 kW	12.30 kW
SCOP	5.05	3.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	10.90 kW
COP Tj = -7°C	3.41	2.48
Pdh Tj = +2°C	6.50 kW	6.70 kW
COP Tj = +2°C	5.08	3.96
Pdh Tj = +7°C	6.90 kW	5.90 kW
COP Tj = +7°C	5.95	4.69
Pdh Tj = 12°C	6.80 kW	6.50 kW
COP Tj = 12°C	7.36	5.81
Pdh Tj = Tbiv	9.70 kW	10.90 kW
COP Tj = Tbiv	3.41	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	25 W	25 W
PTO	7 W	7 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.70 kW
Annual energy consumption Qhe	4508 kWh	6530 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	53 dB(A)	55 dB(A)

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	165 %	134 %
Prated	13.00 kW	14.00 kW
SCOP	4.19	3.41
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = -7°C	7.90 kW	8.50 kW
COP Tj = -7°C	3.50	2.85
Pdh Tj = +2°C	6.20 kW	6.10 kW
COP Tj = +2°C	5.25	4.15
Pdh Tj = +7°C	5.90 kW	6.00 kW
COP Tj = +7°C	5.60	4.80
Pdh Tj = 12°C	6.70 kW	6.40 kW
COP Tj = 12°C	7.00	5.80
Pdh Tj = Tbiv	9.60 kW	10.30 kW
COP Tj = Tbiv	3.15	2.55
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.30 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.94
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	7 W
PSB	25 W	25 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.70 kW	5.30 kW
Annual energy consumption Qhe	7639 kWh	10108 kWh

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	53 dB(A)	55 dB(A)