

#### Page 1 of 4

#### This information was generated by the HP KEYMARK database on 23 Jun 2022

#### <u>Login</u>

Summary of	Intelligent Inverter Heat Pump 20-R290	Reg. No.	041-K020-04
Certificate Holder			
Name	Guangdong PHNIX Eco-Energy Solutions Ltd.		
Address	No. 3 Tianyuan Road Dagang Town	Zip	511470
City	Guangdong	Country	China
Certification Body	BRE Global Limited		
Subtype title	Intelligent Inverter Heat Pump 20-R290		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.5 kg		
Certification Date	16.06.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		



This information was generated by the HP KEYMARK database on 23 Jun 2022

## Model: PASRW020-BP-PS-D

Configure model			
Model name	PASRW020-BP-PS-D		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data			
Power supply 1x230V 50Hz			

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	5.87 kW	6.30 kW	
El input	1.26 kW	2.07 kW	
СОР	4.64	3.04	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

# Average Climate



This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	57 dB(A)	60 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	205 %	150 %
Prated	4.96 kW	4.77 kW
SCOP	5.20	3.83
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.38 kW	4.22 kW
COP Tj = -7°C	3.26	2.33
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.90 kW	2.73 kW
COP Tj = +2°C	4.98	3.68
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.10 kW	2.62 kW
COP Tj = +7°C	6.81	5.07
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	2.50 kW	3.02 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	9.66	7.35
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	4.38 kW	4.22 kW
COP Tj = Tbiv	3.26	2.33
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.09 kW	4.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	67 °C	67 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	42 W	42 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.04 kW
Annual energy consumption Qhe	1970 kWh	2575 kWh