

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Hysae Hybrid	Reg. No.	012-017
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	SP		
Subtype title	Hysae Hybrid		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.05 kg		
Certification Date	20.12.2016		

Model: Hysae Hybrid 6012/28 VR

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature
Heat output	2.96 kW
El input	0.68 kW
COP	4.34
Indoor water flow rate	0.50 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature
Sound power level indoor	47 dB(A)
Sound power level outdoor	58 dB(A)

EN 14825

	Low temperature
η_s	160 %
Prated	4.00 kW
SCOP	4.07
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	4.00 kW
COP Tj = -7°C	2.60
Pdh Tj = +2°C	2.30 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	1.50 kW
COP Tj = +7°C	6.10
Pdh Tj = 12°C	1.70 kW
COP Tj = 12°C	7.40
Cdh	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = Tbiv	4.00 kW
COP Tj = Tbiv	2.60
Pdh Tj = TOL	3.60 kW
COP Tj = TOL	2.40
Cdh	0.90
WTOL	50 °C
Poff	5 W
PTO	20 W
PSB	5 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.80 kW
Annual energy consumption Qhe	2233 kWh

Model: Hysae Hybrid 6012/35

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature
Heat output	2.96 kW
El input	0.68 kW
COP	4.34
Indoor water flow rate	0.50 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature
Sound power level indoor	47 dB(A)
Sound power level outdoor	58 dB(A)

EN 14825

	Low temperature
η_s	160 %
Prated	4.00 kW
SCOP	4.07
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	4.00 kW
COP Tj = -7°C	2.60
Pdh Tj = +2°C	2.30 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	1.50 kW
COP Tj = +7°C	6.10
Pdh Tj = 12°C	1.70 kW
COP Tj = 12°C	7.40
Cdh	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = Tbiv	4.00 kW
COP Tj = Tbiv	2.60
Pdh Tj = TOL	3.60 kW
COP Tj = TOL	2.40
Cdh	0.90
WTOL	50 °C
Poff	5 W
PTO	20 W
PSB	5 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.80 kW
Annual energy consumption Qhe	2233 kWh