

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	DAIKIN ALTHERMA LT MONOBLOC / ROTEX HPSU MONOBLOC 5 KW	Reg. No.	011-1W0079
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA LT MONOBLOC / ROTEX HPSU MONOBLOC 5 KW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.3 kg		

Model: RBLQ05C*V3

Configure model

Model name	RBLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.36 kW	4.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.52	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Q_{he}	2040 kWh	2679 kWh

Model: RDLQ05C*V3

Configure model	
Model name	RDLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.34 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.36 kW	4.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.52	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Q_{he}	2040 kWh	2679 kWh

Model: EDLQ05C*V3

Configure model	
Model name	EDLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.34 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.36 kW	4.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.52	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Q_{he}	2040 kWh	2679 kWh

Model: EBLQ05C*V3

Configure model

Model name	EBLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.36 kW	4.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.52	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Q_{he}	2040 kWh	2679 kWh