

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	01. Yutaki S & S Combi 2.0HP	Reg. No.	041-K002-01
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	01. Yutaki S & S Combi 2.0HP		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.4 kg		

# Model: RAS-2WHVNP RWM-2.0NE - Heating Only

Configure model	
Model name	RAS-2WHVNP RWM-2.0NE - Heating Only
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	189 %	137 %
Prated	4.00 kW	4.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00
Pdh Tj = Tbiv	3.54 kW	3.50 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP $T_j = T_{biv}$	3.20	2.30
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.00 kW	3.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.75	1.90
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
P <sub>off</sub>	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Q <sub>he</sub>	1719 kWh	2358 kWh

# Model: RAS-2WHVNP RWD-2.0NWE-200S - Heating Only

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWE-200S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
EI input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	189 %	137 %
Prated	4.00 kW	4.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1719 kWh	2358 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	132 %
COP	3.30
Heating up time	1:43 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l



# Model: RAS-2WHVNP RWD-2.0NWE-260S - Heating Only

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWE-260S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	189 %	137 %
Prated	4.00 kW	4.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1719 kWh	2358 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

# Model: RAS-2WHVNP RWD-2.0NWE-200S-K - UK- Heating Only

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWE-200S-K - UK- Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	189 %	137 %
Prated	4.00 kW	4.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1719 kWh	2358 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	132 %
COP	3.30
Heating up time	1:43 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l



# Model: RAS-2WHVNP RWD-2.0NWE-260S-K - UK- Heating Only

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWE-260S-K - UK- Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
EI input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	189 %	137 %
Prated	4.00 kW	4.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1719 kWh	2358 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

# Model: RAS-2WHVNP RWD-2.0NWSE-260S - Solar - Heating Only

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWSE-260S - Solar - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	189 %	137 %
Prated	4.00 kW	4.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1719 kWh	2358 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l



# Model: RAS-2WHVNP RWM-2.0NE - with cooling kit

Configure model	
Model name	RAS-2WHVNP RWM-2.0NE - with cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	194 %	140 %
Prated	4.00 kW	4.00 kW
SCOP	4.93	3.58
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1675 kWh	2314 kWh

# Model: RAS-2WHVNP RWD-2.0NWE-200S - with cooling kit

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWE-200S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	194 %	140 %
Prated	4.00 kW	4.00 kW
SCOP	4.93	3.58
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1675 kWh	2314 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	132 %
COP	3.30
Heating up time	1:43 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l

# Model: RAS-2WHVNP RWD-2.0NWE-260S - with cooling kit

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWE-260S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00



## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	194 %	140 %
Prated	4.00 kW	4.00 kW
SCOP	4.93	3.58
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1675 kWh	2314 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

# Model: RAS-2WHVNP RWD-2.0NWSE-260S - Solar - with cooling kit

Configure model	
Model name	RAS-2WHVNP RWD-2.0NWSE-260S - Solar - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	194 %	140 %
Prated	4.00 kW	4.00 kW
SCOP	4.93	3.58
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.30
Pdh Tj = +2°C	2.15 kW	2.10 kW
COP Tj = +2°C	5.20	3.73
Pdh Tj = +7°C	1.70 kW	1.60 kW
COP Tj = +7°C	6.05	4.40
Pdh Tj = 12°C	1.75 kW	1.60 kW
COP Tj = 12°C	6.25	5.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1675 kWh	2314 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l