This information was generated by the HP KEYMARK database on 23 Jun 2022

Login

Summary of	Bosch Compress 7800i LW 16	Reg. No.	011-1W0433
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Bosch Compress 7800i LW 16		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.3 kg		
Certification Date	08.12.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: CS7800i LW 16 M (+MF)

Configure model	
Model name	CS7800i LW 16 M (+MF)
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	15.54 kW	14.19 kW
El input	4.14 kW	5.68 kW
COP	3.75	2.5

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	155 %
Prated	15.53 kW	14.18 kW
SCOP	5.30	4.07
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	15.54 kW	14.19 kW
COP Tj = +2°C	3.75	2.46
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.99 kW	9.32 kW
COP Tj = +7°C	5.05	3.63
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	4.89 kW	4.71 kW
COP Tj = 12°C	5.98	4.98
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	15.54 kW	14.19 kW

COP Tj = Tbiv	3.75	2.46
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.54 kW	14.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.75	2.46
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0 kW
Annual energy consumption Qhe	3916 kWh	4658 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	211 %	161 %

Prated	15.53 kW	14.18 kW
SCOP	5.47	4.24
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.06 kW	8.96 kW
COP Tj = -7°C	5.18	3.86
Cdh Tj = -7 °C	0.99	1.00
Pdh Tj = +2°C	6.2 kW	5.42 kW
COP Tj = +2°C	5.97	4.74
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.91 kW	4.76 kW
COP Tj = +7°C	6.07	5.09
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.88 kW	4.75 kW
COP Tj = 12°C	5.89	5.19
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	15.53 kW	14.19 kW
COP Tj = Tbiv	3.75	2.5
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.54 kW	14.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.75	2.5
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	0.99

WTOL	62 °C	62 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0 kW
Annual energy consumption Qhe	6995 kWh	8251 kWh
Cdh Tj = -15 °C	1.00	1.00

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	203 %	154 %
Prated	15.53 kW	14.18 kW
SCOP	5.28	4.06
Tbiv	-10 °C	-10 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.91 kW	12.81 kW
COP Tj = -7°C	4.07	2.81
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.93 kW	7.91 kW
COP Tj = +2°C	5.39	4.21
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.72 kW	5.4 kW
COP Tj = +7°C	6.04	4.72
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.89 kW	4.7 kW
COP Tj = 12°C	5.98	4.97
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	15.54 kW	14.19 kW
COP Tj = Tbiv	3.75	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.54 kW	14.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.75	2.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	6074 kWh	7218 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	127 %
COP	3.05
Heating up time	1:09 h:min
Standby power input	43.1 W
Reference hot water temperature	46.9 °C
Mixed water at 40°C	206 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	127 %
COP	3.05
Heating up time	1:09 h:min
Standby power input	43.1 W
Reference hot water temperature	46.9 °C
Mixed water at 40°C	206 l

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	127 %
COP	3.05
Heating up time	1:09 h:min
Standby power input	43.1 W
Reference hot water temperature	46.9 °C
Mixed water at 40°C	206 l

Model: CS7800i LW 16 (+F)

Configure model	
Model name	CS7800i LW 16 (+F)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	15.54 kW	14.19 kW
El input	4.14 kW	5.68 kW
COP	3.75	2.5

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	204 %	155 %
Prated	15.53 kW	14.18 kW
SCOP	5.30	4.07
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	15.54 kW	14.19 kW
COP Tj = +2°C	3.75	2.46
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.99 kW	9.32 kW
COP Tj = +7°C	5.05	3.63
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	4.89 kW	4.71 kW
COP Tj = 12°C	5.98	4.98
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	15.54 kW	14.19 kW

COP Tj = Tbiv	3.75	2.46
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.54 kW	14.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.75	2.46
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0 kW
Annual energy consumption Qhe	3916 kWh	4658 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	211 %	161 %

Prated	15.53 kW	14.18 kW
SCOP	5.47	4.24
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.06 kW	8.96 kW
COP Tj = -7°C	5.18	3.86
Cdh Tj = -7 °C	0.99	1.00
Pdh Tj = +2°C	6.2 kW	5.42 kW
COP Tj = +2°C	5.97	4.74
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.91 kW	4.76 kW
COP Tj = +7°C	6.07	5.09
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.88 kW	4.75 kW
COP Tj = 12°C	5.89	5.19
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	15.53 kW	14.19 kW
COP Tj = Tbiv	3.75	2.5
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.54 kW	14.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.75	2.5
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	0.99

WTOL	62 °C	62 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0 kW
Annual energy consumption Qhe	6995 kWh	8251 kWh
Cdh Tj = -15 °C	1.00	1.00

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	203 %	154 %
Prated	15.53 kW	14.18 kW
SCOP	5.28	4.06
Tbiv	-10 °C	-10 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.91 kW	12.81 kW
COP Tj = -7°C	4.07	2.81
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.93 kW	7.91 kW
COP Tj = +2°C	5.39	4.21
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.72 kW	5.4 kW
COP Tj = +7°C	6.04	4.72
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.89 kW	4.7 kW
COP Tj = 12°C	5.98	4.97
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	15.54 kW	14.19 kW
COP Tj = Tbiv	3.75	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.54 kW	14.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.75	2.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	6074 kWh	7218 kWh