

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	FUJITSU Waterstage Split Comfort Series 10	Reg. No.	012-C700106
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	FUJITSU Waterstage Split Comfort Series 10		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.63 kg		
Certification Date	27.04.2021		
Testing basis	HP Keymark Scheme Rules rev 8		

Model: FUJITSU Waterstage Split Comfort Series 10

Configure model	
Model name	FUJITSU Waterstage Split Comfort Series 10
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.50 kW	9.00 kW
El input	2.10 kW	3.33 kW
COP	4.50	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	130 %
Prated	8.50 kW	8.20 kW
SCOP	4.53	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.30 kW
COP Tj = -7°C	2.98	2.05
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	4.60 kW	4.40 kW
COP Tj = +2°C	4.46	3.24
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	3.90 kW	3.50 kW
COP Tj = +7°C	5.89	4.60
Cdh Tj = +7 °C	0.970	0.970

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.40 kW	4.30 kW
COP Tj = 12°C	7.14	5.97
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	7.50 kW	7.30 kW
COP Tj = Tbiv	2.98	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.30 kW	7.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	20 W	21 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.20 kW	1.10 kW
Annual energy consumption Qhe	3875 kWh	5083 kWh

Model: FUJITSU Waterstage Split Comfort Series Integrated DHW 10

Configure model	
Model name	FUJITSU Waterstage Split Comfort Series Integrated DHW 10
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.50 kW	9.00 kW
El input	2.10 kW	3.33 kW
COP	4.50	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	130 %
Prated	8.50 kW	8.20 kW
SCOP	4.53	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.30 kW
COP Tj = -7°C	2.98	2.05
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	4.60 kW	4.40 kW
COP Tj = +2°C	4.46	3.24
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	3.90 kW	3.50 kW
COP Tj = +7°C	5.89	4.60
Cdh Tj = +7 °C	0.970	0.970

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.40 kW	4.30 kW
COP Tj = 12°C	7.14	5.97
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	7.50 kW	7.30 kW
COP Tj = Tbiv	2.98	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.30 kW	7.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	20 W	21 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.20 kW	1.10 kW
Annual energy consumption Qhe	3875 kWh	5083 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.10
Heating up time	1:15 h:min
Standby power input	35.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	245 l