

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	InelioDynamic 08	Reg. No.	ICIM-PDC-000100-00
Certificate Holder			
Name	FHE Manufacturing		
Address	Parc Atlantic Free Zone - Commune Amer Selfia - RN4 - Lot. 210	Zip	
City	Kenitra	Country	Morocco
Certification Body	ICIM S.p.A.		
Subtype title	InelioDynamic 08		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.3 kg		
Certification Date	16.06.2021		

Model: InelioDynamic 08

Configure model	
Model name	InelioDynamic 08
Application	Heating + DHW + low temp
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.80 kW	4.16 kW
El input	1.41 kW	1.97 kW
COP	4.12	2.11

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	153 %	111 %
Prated	4.73 kW	3.51 kW
SCOP	3.89	2.85
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.18 kW	3.10 kW
COP Tj = -7°C	2.47	1.70
Pdh Tj = +2°C	2.49 kW	1.95 kW
COP Tj = +2°C	3.79	2.85
Pdh Tj = +7°C	1.66 kW	1.43 kW
COP Tj = +7°C	5.21	3.85
Pdh Tj = 12°C	1.16 kW	1.29 kW
COP Tj = 12°C	6.39	5.24
Pdh Tj = Tbiv	4.18 kW	3.10 kW
COP Tj = Tbiv	2.47	1.70

This information was generated by the HP KEYMARK database on 22 Jun 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.62 kW	2.19 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.03	1.12
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
Poff	5 W	5 W
PTO	8 W	8 W
PSB	5 W	5 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	1.32 kW
Annual energy consumption Q_{he}	2509 kWh	2546 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	91 %
COP	2.18
Heating up time	4:04 h:min
Standby power input	54.3 W
Reference hot water temperature	46.7 °C
Mixed water at 40°C	364 l