

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Assure Mono 5 7 9	Reg. No.	ICIM-PDC-000081-00
Certificate Holder			
Name	BAXI Heating UK Limited		
Address	Acordn House, Coventry road	Zip	CV34 4RT
City	Warwick	Country	United Kingdom
Certification Body	ICIM S.p.A.		
Name of testing laboratory	OBL certificate		
Subtype title	Assure Mono 5 7 9		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	2 kg		
Certification Date	25.06.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: Assure Mono 5

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.65 kW	4.65 kW
El input	0.93 kW	1.77 kW
COP	5.00	2.63
Indoor water flow rate	0.80 m ³ /h	0.50 m ³ /h

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %

This information was generated by the HP KEYMARK database on 17 Dec 2020

Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21
Cdh	0.90	0.90
Pdh Tj = 12°C	1.03 kW	1.26 kW
COP Tj = 12°C	5.89	4.91
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL	6.62 kW	5.86 kW
COP Tj = TOL	2.63	1.62
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	9 W	9 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3071 kWh	4203 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

Model: Assure Mono 7

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.65 kW	6.80 kW
El input	1.35 kW	2.42 kW
COP	4.94	2.81
Indoor water flow rate	1.14 m ³ /h	0.73 m ³ /h

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %

This information was generated by the HP KEYMARK database on 17 Dec 2020

Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21
Cdh	0.90	0.90
Pdh Tj = 12°C	1.03 kW	1.26 kW
COP Tj = 12°C	5.89	4.91
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL	6.62 kW	5.86 kW
COP Tj = TOL	2.63	1.62
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	6 W	6 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3701 kWh	4203 kWh

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

Model: Assure Mono 9

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.60 kW	8.60 kW
El input	1.87 kW	3.12 kW
COP	4.60	2.75
Indoor water flow rate	1.48 m ³ /h	0.92 m ³ /h

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	177 %	126 %

This information was generated by the HP KEYMARK database on 17 Dec 2020

Prated	8.00 kW	7.00 kW
SCOP	4.51	3.22
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.42 kW	6.58 kW
COP Tj = -7°C	2.80	1.87
Cdh	0.90	0.90
Pdh Tj = +2°C	4.83 kW	4.25 kW
COP Tj = +2°C	4.33	3.19
Cdh	0.90	0.90
Pdh Tj = +7°C	3.20 kW	2.80 kW
COP Tj = +7°C	6.20	4.38
Cdh	0.90	0.90
Pdh Tj = 12°C	1.55 kW	1.27 kW
COP Tj = 12°C	7.61	5.04
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.42 kW	6.58 kW
COP Tj = Tbiv	2.80	1.87
Pdh Tj = TOL	6.64 kW	5.53 kW
COP Tj = TOL	2.54	1.51
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	10 W	10 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	1.80 kW	1.80 kW
Annual energy consumption Qhe	3844 kWh	4770 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)