Summary of	DAIKIN ALTHERMA 3 R W 6KW /A	Reg. No.	011-1W0246
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	Danish Technological Institute		
Subtype title	DAIKIN ALTHERMA 3 R W 6KW /A		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	1.5 kg		
Certification Date	02.03.2018		

Model: ERGA06DVA / EHBH08D6V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m^3/h	0.71 m^3/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Model: ERGA06DVA / EHBH08D9W

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m³/h	0.71 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Model: ERGA06DVA / EHBX08D6V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m³/h	0.71 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

Model: ERGA06DVA / EHBX08D9W

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m^3/h	0.71 m^3/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

Model: ERGA06EVA / EHBX08E6V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m^3/h	0.71 m^3/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

Cooling

EN 14825

	+7°C/+12°C
Pdesignc	5.10 kW
SEER	5.73
Pdc Tj = 35°C	5.09 kW
EER Tj = 35°C	3.28
Pdc Tj = 30°C	3.75 kW
EER Tj = 30°C	4.93
Cdc	1.0
Pdc Tj = 25°C	2.47 kW
EER Tj = 25°C	6.86
Cdc	1.0
Pdc Tj = 20°C	2.52 kW
EER Tj = 20°C	8.36
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	533 kWh

EN 14511-2	
	+7°C/+12°C
El input	1.55 kW
Indoor water flow rate	0.88 m³/h
Cooling capacity	5.09
EER	3.28

Model: ERGA06EVA / EHBX08E9W

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m^3/h	0.71 m^3/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

Cooling

EN 14825

	+7°C/+12°C
Pdesignc	5.10 kW
SEER	5.73
Pdc Tj = 35°C	5.09 kW
EER Tj = 35°C	3.28
Pdc Tj = 30°C	3.75 kW
EER Tj = 30°C	4.93
Cdc	1.0
Pdc Tj = 25°C	2.47 kW
EER Tj = 25°C	6.86
Cdc	1.0
Pdc Tj = 20°C	2.52 kW
EER Tj = 20°C	8.36
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	533 kWh

EN 14511-2	
	+7°C/+12°C
El input	1.55 kW
Indoor water flow rate	0.88 m³/h
Cooling capacity	5.09
EER	3.28

Model: ERGA06EVA / EHBH08E6V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m³/h	0.71 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Cooling

EN 14825

	+7°C/+12°C
Pdesignc	5.10 kW
SEER	5.73
Pdc Tj = 35°C	5.09 kW
EER Tj = 35°C	3.28
Pdc Tj = 30°C	3.75 kW
EER Tj = 30°C	4.93
Cdc	1.0
Pdc Tj = 25°C	2.47 kW
EER Tj = 25°C	6.86
Cdc	1.0
Pdc Tj = 20°C	2.52 kW
EER Tj = 20°C	8.36
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	533 kWh

EN 14511-2	
	+7°C/+12°C
El input	1.55 kW
Indoor water flow rate	0.88 m³/h
Cooling capacity	5.09
EER	3.28

Model: ERGA06EVA / EHBH08E9W

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70
Indoor water flow rate	1.03 m^3/h	0.71 m^3/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh		1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL	6.00 kW	4.50 kW
COP Tj = TOL	2.49	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Cooling

EN 14825

	+7°C/+12°C
Pdesignc	5.10 kW
SEER	5.73
Pdc Tj = 35°C	5.09 kW
EER Tj = 35°C	3.28
Pdc Tj = 30°C	3.75 kW
EER Tj = 30°C	4.93
Cdc	1.0
Pdc Tj = 25°C	2.47 kW
EER Tj = 25°C	6.86
Cdc	1.0
Pdc Tj = 20°C	2.52 kW
EER Tj = 20°C	8.36
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	533 kWh

EN 14511-2	
	+7°C/+12°C
El input	1.55 kW
Indoor water flow rate	0.88 m³/h
Cooling capacity	5.09
EER	3.28