

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	19. Yutaki M 4.0HP (mono)	Reg. No.	041-K002-19
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	CEIS		
Subtype title	19. Yutaki M 4.0HP (mono)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.8 kg		

Model: RASM-4VNE - Heating Only

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00
Indoor water flow rate	1.89 m ³ /h	1.18 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	187 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.75	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.60 kW	8.60 kW
COP Tj = -7°C	2.74	1.80
Pdh Tj = +2°C	5.84 kW	5.23 kW
COP Tj = +2°C	5.20	3.60
Pdh Tj = +7°C	3.76 kW	3.52 kW
COP Tj = +7°C	5.80	4.80
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	6.40	5.80
Pdh Tj = Tbiv	9.60 kW	8.60 kW
COP Tj = Tbiv	2.74	1.80

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	10.50 kW	8.80 kW
COP Tj = TOL	2.65	1.90
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	13 W	13 W
PTO	0 W	0 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	4714 kWh	5786 kWh

Model: RASM-4VNE - with cooling kit

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00
Indoor water flow rate	1.89 m ³ /h	1.18 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	137 %
Prated	11.00 kW	10.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.60 kW	8.60 kW
COP Tj = -7°C	2.74	1.80
Pdh Tj = +2°C	5.84 kW	5.23 kW
COP Tj = +2°C	5.20	3.60
Pdh Tj = +7°C	3.76 kW	3.52 kW
COP Tj = +7°C	5.80	4.80
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	6.40	5.80
Pdh Tj = Tbiv	9.60 kW	8.60 kW
COP Tj = Tbiv	2.74	1.80

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	10.50 kW	8.80 kW
COP Tj = TOL	2.65	1.90
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	13 W	13 W
PTO	0 W	0 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	4666 kWh	5738 kWh