

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Austria Email LWPM 11	Reg. No.	012-C700118
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Austria Email LWPM 11		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R452B		
Mass of Refrigerant	2.85 kg		
Certification Date	12.11.2021		
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017		

Model: Austria Email LWPM 11

Configure model	
Model name	Austria Email LWPM 11
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.81 kW	9.28 kW
El input	1.29 kW	3.29 kW
COP	4.52	2.82

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	9.80 kW	9.60 kW
SCOP	4.45	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.70 kW	8.50 kW
COP Tj = -7°C	3.07	2.22
Cdh Tj = -7 °C	0.970	0.980
Pdh Tj = +2°C	5.30 kW	5.20 kW
COP Tj = +2°C	4.58	3.35
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	6.00 kW	5.90 kW
COP Tj = +7°C	5.42	4.19
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	7.00 kW	6.80 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	6.55	5.18
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	8.70 kW	8.50 kW
COP Tj = Tbiv	3.07	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.90 kW	7.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	36 W	25 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	1.90 kW
Annual energy consumption Qhe	4552 kWh	5964 kWh