Login

Summary of	WPF 10, WPF 10 cool, WPC 10, WPC 10 cool	Reg. No.	011-1W0010
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 10, WPF 10 cool, WPC 10, WPC 10 cool		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.03 kg		
Certification Date	23.08.2016		

Model: WPF 10

Configure model	
Model name	WPF 10
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	10.31 kW	9.28 kW
El input	2.05 kW	3.18 kW
COP	5.02	2.91

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	136 %
Prated	10.00 kW	9.00 kW
SCOP	5.59	3.60
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
COP Tj = -7°C	0.00	0.00
Pdh Tj = +2°C	10.30 kW	9.10 kW
COP Tj = +2°C	5.03	2.83
Pdh Tj = +7°C	10.40 kW	9.50 kW
COP Tj = +7°C	5.43	3.28
Pdh Tj = 12°C	10.60 kW	10.00 kW
COP Tj = 12°C	6.10	4.21
Pdh Tj = Tbiv	10.30 kW	9.10 kW

COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	91.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.03	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2466 kWh	3367 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	224 %	224 %
Prated	13.00 kW	13.00 kW
SCOP	5.81	5.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.50 kW	10.50 kW
COP Tj = -7°C	5.75	5.74
Pdh Tj = +2°C	10.60 kW	10.60 kW
COP Tj = +2°C	6.07	6.07
Pdh Tj = +7°C	10.70 kW	10.70 kW
COP Tj = +7°C	6.36	6.36
Pdh Tj = 12°C	10.70 kW	10.70 kW
COP Tj = 12°C	6.40	6.40
Pdh Tj = Tbiv	10.50 kW	10.50 kW
COP Tj = Tbiv	5.60	5.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	5.03
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C

Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.55 kW	2.55 kW
Annual energy consumption Qhe	5457 kWh	5457 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	216 %	137 %
Prated	10.00 kW	9.00 kW
SCOP	5.61	3.63
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C

Pdh Tj = -7°C	9.20 kW	9.20 kW
COP Tj = -7°C	2.97	2.97
Pdh Tj = +2°C	9.60 kW	9.60 kW
COP Tj = +2°C	3.56	3.56
Pdh Tj = +7°C	9.90 kW	9.90 kW
COP Tj = +7°C	4.03	4.03
Pdh Tj = 12°C	10.10 kW	10.10 kW
COP Tj = 12°C	4.60	4.60
Pdh Tj = Tbiv	10.30 kW	9.10 kW
COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	3799 kWh	5167 kWh

Model: WPF 10 cool

Configure model	
Model name	WPF 10 cool
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	10.31 kW	9.28 kW
El input	2.05 kW	3.18 kW
COP	5.02	2.91

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	136 %
Prated	10.00 kW	9.00 kW
SCOP	5.59	3.60
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
COP Tj = -7°C	0.00	0.00
Pdh Tj = +2°C	10.30 kW	9.10 kW
COP Tj = +2°C	5.03	2.83
Pdh Tj = +7°C	10.40 kW	9.50 kW
COP Tj = +7°C	5.43	3.28
Pdh Tj = 12°C	10.60 kW	10.00 kW
COP Tj = 12°C	6.10	4.21
Pdh Tj = Tbiv	10.30 kW	9.10 kW

COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	91.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.03	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2466 kWh	3367 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	224 %	224 %
Prated	13.00 kW	13.00 kW
SCOP	5.81	5.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.50 kW	10.60 kW
COP Tj = -7°C	5.75	6.07
Pdh Tj = +2°C	10.60 kW	10.70 kW
COP Tj = +2°C	6.07	6.36
Pdh Tj = +7°C	10.70 kW	10.70 kW
COP Tj = +7°C	6.36	6.36
Pdh Tj = 12°C	10.70 kW	10.47 kW
COP Tj = 12°C	6.40	6.40
Pdh Tj = Tbiv	10.50 kW	10.50 kW
COP Tj = Tbiv	5.60	5.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	5.03
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C

Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.55 kW	0.00 kW
Annual energy consumption Qhe	5457 kWh	5457 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	216 %	137 %
Prated	10.00 kW	9.00 kW
SCOP	5.61	3.63
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C

Pdh Tj = -7°C	9.20 kW	9.20 kW
COP Tj = -7°C	2.97	2.97
Pdh Tj = +2°C	9.60 kW	9.60 kW
COP Tj = +2°C	3.56	3.56
Pdh Tj = +7°C	9.90 kW	9.90 kW
COP Tj = +7°C	4.03	4.03
Pdh Tj = 12°C	10.10 kW	10.10 kW
COP Tj = 12°C	4.60	4.60
Pdh Tj = Tbiv	10.30 kW	9.10 kW
COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	3799 kWh	5167 kWh

Model: WPC 10

Configure model	
Model name	WPC 10
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	10.31 kW	9.28 kW
El input	2.05 kW	3.18 kW
COP	5.02	2.91

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	52 dB(A)	52 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	136 %
Prated	10.00 kW	9.00 kW
SCOP	5.59	3.60
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
COP Tj = -7°C	0.00	0.00
Pdh Tj = +2°C	10.30 kW	9.10 kW
COP Tj = +2°C	5.03	2.83
Pdh Tj = +7°C	10.40 kW	9.50 kW
COP Tj = +7°C	5.43	3.28
Pdh Tj = 12°C	10.60 kW	10.00 kW
COP Tj = 12°C	6.10	4.21
Pdh Tj = Tbiv	10.30 kW	9.10 kW

COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.03	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2466 kWh	3367 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	52 dB(A)	52 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	224 %	144 %
Prated	13.00 kW	12.00 kW
SCOP	5.81	5.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.50 kW	9.60 kW
COP Tj = -7°C	5.75	3.55
Pdh Tj = +2°C	10.60 kW	9.90 kW
COP Tj = +2°C	6.07	4.03
Pdh Tj = +7°C	10.70 kW	10.10 kW
COP Tj = +7°C	6.36	4.48
Pdh Tj = 12°C	10.70 kW	10.30 kW
COP Tj = 12°C	6.40	4.87
Pdh Tj = Tbiv	10.50 kW	9.50 kW
COP Tj = Tbiv	5.60	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C

Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.55 kW	2.50 kW
Annual energy consumption Qhe	5457 kWh	7549 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	52 dB(A)	52 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	216 %	137 %
Prated	10.00 kW	9.00 kW
SCOP	5.61	3.63
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C

Pdh Tj = -7°C	9.20 kW	9.20 kW
COP Tj = -7°C	2.97	2.97
Pdh Tj = +2°C	9.60 kW	9.60 kW
COP Tj = +2°C	3.56	3.56
Pdh Tj = +7°C	9.90 kW	9.90 kW
COP Tj = +7°C	4.03	4.03
Pdh Tj = 12°C	10.10 kW	10.10 kW
COP Tj = 12°C	4.60	4.60
Pdh Tj = Tbiv	10.30 kW	9.10 kW
COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	3799 kWh	5167 kWh

Model: WPC 10 cool

Configure model	
Model name	WPC 10 cool
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	10.31 kW	9.28 kW
El input	2.05 kW	3.18 kW
COP	5.02	2.91

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	52 dB(A)	52 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	136 %
Prated	10.00 kW	9.00 kW
SCOP	5.59	3.60
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
COP Tj = -7°C	0.00	0.00
Pdh Tj = +2°C	10.30 kW	9.10 kW
COP Tj = +2°C	5.03	2.83
Pdh Tj = +7°C	10.40 kW	9.50 kW
COP Tj = +7°C	5.43	3.28
Pdh Tj = 12°C	10.60 kW	10.00 kW
COP Tj = 12°C	6.10	4.21
Pdh Tj = Tbiv	10.30 kW	9.10 kW

COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.03	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2466 kWh	3367 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	52 dB(A)	52 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	224 %	144 %
Prated	13.00 kW	12.00 kW
SCOP	5.81	3.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.50 kW	9.60 kW
COP Tj = -7°C	5.75	3.55
Pdh Tj = +2°C	10.60 kW	9.90 kW
COP Tj = +2°C	6.07	4.03
Pdh Tj = +7°C	10.70 kW	10.10 kW
COP Tj = +7°C	6.36	4.48
Pdh Tj = 12°C	10.70 kW	10.30 kW
COP Tj = 12°C	6.40	4.87
Pdh Tj = Tbiv	10.50 kW	9.50 kW
COP Tj = Tbiv	5.60	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C

Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.55 kW	2.50 kW
Annual energy consumption Qhe	5457 kWh	7549 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	52 dB(A)	52 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	216 %	137 %
Prated	10.00 kW	9.00 kW
SCOP	5.61	3.63
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C

Pdh Tj = -7°C	9.20 kW	9.20 kW
COP Tj = -7°C	2.97	2.97
Pdh Tj = +2°C	9.60 kW	9.60 kW
COP Tj = +2°C	3.56	3.56
Pdh Tj = +7°C	9.90 kW	9.90 kW
COP Tj = +7°C	4.03	4.03
Pdh Tj = 12°C	10.10 kW	10.10 kW
COP Tj = 12°C	4.60	4.60
Pdh Tj = Tbiv	10.30 kW	9.10 kW
COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	3799 kWh	5167 kWh