

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	DAIKIN ALTHERMA 3 R F 06KW (230L)	Reg. No.	011-1W0220
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 R F 06KW (230L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	22.11.2017		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)		

Model: ERGA06EV / EHVH08S23E(6V/9W)

Configure model	
Model name	ERGA06EV / EHVH08S23E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EV / EHVH08SU23E6V

Configure model	
Model name	ERGA06EV / EHVH08SU23E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EV / EHVX08S23E6V(G)

Configure model	
Model name	ERGA06EV / EHVX08S23E6V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.28
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3196 kWh	4405 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EV / EHVX08S23E9W

Configure model	
Model name	ERGA06EV / EHVX08S23E9W
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.28
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3196 kWh	4405 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EV / EHVZ08S23E(6V/9W)

Configure model	
Model name	ERGA06EV / EHVZ08S23E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EV / EHVH08S23E(6V/9W) + cooling kit

Configure model	
Model name	ERGA06EV / EHVH08S23E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EV / EHVZ08S23E(6V/9W) + cooling kit

Configure model	
Model name	ERGA06EV / EHVZ08S23E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.10 kW	6.10 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.60 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EVH / EHVH08S23E(6V/9W)

Configure model	
Model name	ERGA06EVH / EHVH08S23E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.0 kW	7.0 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.0 kW	5.9 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.9 kW	3.9 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.1 kW	6.1 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.0 kW	5.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.0 kW	1.6 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EVH / EHVH08SU23E6V

Configure model	
Model name	ERGA06EVH / EHVH08SU23E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.0 kW	7.0 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.0 kW	5.9 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.9 kW	3.9 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.1 kW	6.1 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.0 kW	5.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.0 kW	1.6 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EVH / EHVX08S23E(6V/9W)

Configure model	
Model name	ERGA06EVH / EHVX08S23E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.0 kW	7.0 kW
SCOP	4.52	3.28
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.0 kW	5.9 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.9 kW	3.9 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.1 kW	6.1 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.0 kW	5.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.0 kW	1.6 kW
Annual energy consumption Qhe	3196 kWh	4405 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EVH / EHVZ08S23E(6V/9W)

Configure model	
Model name	ERGA06EVH / EHVZ08S23E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.0 kW	7.0 kW
SCOP	4.47	3.26
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.0 kW	5.9 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.9 kW	3.9 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.1 kW	6.1 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.0 kW	5.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.0 kW	1.6 kW
Annual energy consumption Qhe	3233 kWh	4441 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EVH / EHVH08S23E(6V/9W) + cooling kit

Configure model	
Model name	ERGA06EVH / EHVH08S23E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.0 kW	7.0 kW
SCOP	4.52	3.28
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.0 kW	5.9 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.9 kW	3.9 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.1 kW	6.1 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.0 kW	5.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.0 kW	1.6 kW
Annual energy consumption Qhe	3196 kWh	4405 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min

Model: ERGA06EVH / EHVZ08S23E(6V/9W) + cooling kit

Configure model	
Model name	ERGA06EVH / EHVZ08S23E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.55 kW
Cooling capacity	5.09
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	5.10 kW
SEER	5.73
P _{dc} T _j = 35°C	5.09 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	3.75 kW
EER T _j = 30°C	4.93
C _{dc}	1.0
P _{dc} T _j = 25°C	2.47 kW
EER T _j = 25°C	6.86
C _{dc}	1.0
P _{dc} T _j = 20°C	2.52 kW
EER T _j = 20°C	8.36
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	533 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.0 kW	7.0 kW
SCOP	4.52	3.28
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.0 kW	5.9 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	n/a	1.0
Pdh Tj = +2°C	3.9 kW	3.9 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.1 kW	6.1 kW
COP Tj = Tbiv	3.07	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.0 kW	5.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.53
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.0 kW	1.6 kW
Annual energy consumption Qhe	3196 kWh	4405 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
COP	3.30
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l
Efficiency η_{DHW}	133 %
Heating up time	1:47 h:min