

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	VWF 117/4	Reg. No.	40046300
Certificate Holder			
Name	Vaillant Deutschland GmbH & Co KG		
Address	Berghauser Straße 40	Zip	42859
City	Remscheid	Country	Germany
Certification Body	VDE Prüf- und Zertifizierungsinstitut GmbH		
Subtype title	VWF 117/4		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	28.04.2021		
Testing basis	DIN EN 14511-1:2019-07; EN 14511-1:2018 DIN EN 14511-2:2019-07; EN 14511-2:2018 DIN EN 14511-3:2019-07; EN 14511-3:2018 DIN EN 14511-4:2019-07; EN 14511-4:2018 EN 12102-1:2018-02; EN 12102-1:2017		

Model: VWF 118/4

Configure model	
Model name	VWF 118/4
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.18 kW	11.33 kW
El input	2.34 kW	3.66 kW
COP	4.77	3.10

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	47 dB(A)
Sound power level outdoor	- dB(A)	- dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	201 %	142 %
Prated	11.18 kW	11.33 kW
SCOP	5.22	3.76
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.18 kW	11.32 kW
COP Tj = -7°C	4.83	3.21
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	11.16 kW	11.26 kW
COP Tj = +2°C	5.15	3.70
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	11.14 kW	11.23 kW
COP Tj = +7°C	5.49	4.08
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = 12°C	11.13 kW	11.19 kW
COP Tj = 12°C	5.87	4.56
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.18 kW	11.33 kW
COP Tj = Tbiv	4.77	3.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.18 kW	11.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.77	3.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	4 W	4 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4427 kWh	6227 kWh

Model: VWF 117/4

Configure model	
Model name	VWF 117/4
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.18 kW	11.33 kW
El input	2.34 kW	3.66 kW
COP	4.77	3.10

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	47 dB(A)
Sound power level outdoor	- dB(A)	- dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	201 %	142 %
Prated	11.18 kW	11.33 kW
SCOP	5.22	3.76
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.18 kW	11.32 kW
COP Tj = -7°C	4.83	3.21
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	11.16 kW	11.26 kW
COP Tj = +2°C	5.15	3.70
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	11.14 kW	11.23 kW
COP Tj = +7°C	5.49	4.08
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = 12°C	11.13 kW	11.19 kW
COP Tj = 12°C	5.87	4.56
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.18 kW	11.33 kW
COP Tj = Tbiv	4.77	3.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.18 kW	11.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.77	3.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	4 W	4 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4427 kWh	6227 kWh