

Page 1 of 11

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	TERRA 8 HPLB	Reg. No.	011-1W0417
Certificate Holder			
Name	Ochsner Wärmepumpen Gmb	Ochsner Wärmepumpen GmbH	
Address	Krackowizerstraße 4	Zip	4020
City	Linz	Country	Austria
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TERRA 8 HPLB		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.9 kg		
Certification Date	30.09.2020	30.09.2020	
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: TERRA 8 HPLB, low temperature, all climates

Configure model		
Model name	TERRA 8 HPLB, low temperature, all climates	
Application	Heating (low temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Average Climate

EN 14825	
	Low temperature
η_{S}	204 %
Prated	8.00 kW
SCOP	5.30
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	7.60 kW
COP Tj = -7°C	4.82
Cdh Tj = -7 °C	
Pdh Tj = $+2$ °C	7.70 kW
$COP Tj = +2^{\circ}C$	5.22

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the	THE KETMANK database on 10 Mai 202
Cdh Tj = +2 °C	
Pdh Tj = +7°C	7.80 kW
$COP Tj = +7^{\circ}C$	5.62
Cdh Tj = +7 °C	
Pdh Tj = 12°C	7.80 kW
COP Tj = 12°C	6.08
Cdh Tj = +12 °C	
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	4.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.76
WTOL	60 °C
Poff	0 W
РТО	55 W
PSB	10 W
PCK	o w
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2964 kWh



EN 12102-1	
	Low temperature
Sound power level indoor	50 dB(A)

Heating

EN 14511-2	
	Low temperature
Heat output	7.60 kW
El input	1.60 kW
СОР	4.76

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 14825	
	Low temperature
η_s	204 %





Prated	8.00 kW
SCOP	5.01
Tbiv	2 °C
TOL	2 °C
Pdh Tj = +2°C	7.60 kW
COP Tj = +2°C	4.76
Cdh Tj = +2 °C	
Pdh Tj = $+7^{\circ}$ C	7.70 kW
$COP Tj = +7^{\circ}C$	5.13
Cdh Tj = +7 °C	
Pdh Tj = 12°C	7.80 kW
COP Tj = 12°C	5.77
Cdh Tj = +12 °C	
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	4.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.76
WTOL	60 °C
Poff	o w
РТО	55 W
PSB	10 W





PCK	o w
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1918 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	50 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_s	212 %
Prated	9.00 kW
SCOP	5.24
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	7.70 kW
$COP Tj = -7^{\circ}C$	5.42
Cdh Tj = -7 °C	
Pdh Tj = +2°C	7.80 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = +2°C	5.74
COP 1J = +2 C	5.74
Cdh Tj = +2 °C	
Pdh Tj = $+7$ °C	7.80 kW
$COP Tj = +7^{\circ}C$	6.01
Cdh Tj = +7 °C	
Pdh Tj = 12°C	7.80 kW
COP Tj = 12°C	6.05
Cdh Tj = +12 °C	
Pdh Tj = Tbiv	7.70 kW
COP Tj = Tbiv	5.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.29
WTOL	60 °C
Poff	o w
РТО	55 W
PSB	10 W
PCK	o w
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.84 kW
Annual energy consumption Qhe	4238 kWh





EN 12102-1	
	Low temperature
Sound power level indoor	50 dB(A)

Model: TERRA 8 HPLB, average climate

Configure model		
Model name	TERRA 8 HPLB, average climate	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	


General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.60 kW	6.90 kW
El input	1.60 kW	2.53 kW
СОР	4.76	2.73

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate





EN 14825

	Low temperature	Medium temperature
n _s	204 %	131 %
Prated	8.00 kW	7.00 kW
SCOP	5.30	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.60 kW	7.00 kW
COP Tj = -7°C	4.82	2.86
Cdh Tj = -7 °C		
Pdh Tj = +2°C	7.70 kW	7.20 kW
COP Tj = +2°C	5.22	3.41
Cdh Tj = +2 °C		
Pdh Tj = $+7^{\circ}$ C	7.80 kW	7.40 kW
COP Tj = +7°C	5.62	3.85
Cdh Tj = +7 °C		
Pdh Tj = 12°C	7.80 kW	7.50 kW
COP Tj = 12°C	6.08	4.39
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	7.60 kW	6.90 kW
COP Tj = Tbiv	4.76	2.73

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 11 of 11

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.60 kW	6.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.76	2.73
WTOL	60 °C	60 °C
Poff	0 W	0 W
РТО	55 W	55 W
PSB	10 W	10 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2964 kWh	4113 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)