

Summary of	L12 Split	Reg. No.	012-C700072
Certificate Holder			
Name	ait-deutschland Gn	nbH	
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	L12 Split		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.9 kg		
Certification Date	29.04.2020		
Testing basis	HP Keymark Scheme 2018		



# Model: alpha innotec L12 Split-HT 12

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.21 kW	4.73 kW
El input	1.09 kW	1.54 kW
СОР	4.78	3.07
Indoor water flow rate	0.89 m³/h	0.51 m³/h

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	



 $$\operatorname{\textit{Page}}\ 3$$  of 9 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	174 %	132 %
Prated	11.50 kW	10.00 kW
SCOP	4.42	3.37
Tbiv	-7 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	8.90 kW
COP Tj = -7°C	2.91	1.99
Pdh Tj = +2°C	6.30 kW	5.50 kW
COP Tj = +2°C	4.34	3.22
Pdh Tj = +7°C	4.10 kW	3.50 kW
COP Tj = +7°C	5.51	4.61
Pdh Tj = 12°C	4.80 kW	5.00 kW
COP Tj = 12°C	6.96	6.25
Pdh Tj = Tbiv	10.20 kW	9.20 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



COP Tj = Tbiv	2.89	1.90
Pdh Tj = TOL	9.30 kW	8.10 kW
COP Tj = TOL	2.66	1.92
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	2 W	2 W
РТО	20 W	15 W
PSB	15 W	15 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.20 kW	1.90 kW
Annual energy consumption Qhe	5482 kWh	6136 kWh

Domestic Hot Water (DHW)





EN 16147	
Declared load profile	XL
Efficiency ηDHW	98 %
СОР	2.32
Heating up time	1:00 h:min
Standby power input	85.0 W
Reference hot water temperature	51.0 °C
Mixed water at 40°C	230 I



## **Model: NOVELAN L12 Split-CS 12**

General Data		
Power supply	n/a	

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.21 kW	4.73 kW
El input	1.09 kW	1.54 kW
СОР	4.78	3.07
Indoor water flow rate	0.89 m³/h	0.51 m³/h

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	




 $$\operatorname{\textit{Page}}\ 7$$  of 9 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	174 %	132 %
Prated	11.50 kW	10.00 kW
SCOP	4.42	3.37
Tbiv	-7 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	8.90 kW
COP Tj = -7°C	2.91	1.99
Pdh Tj = +2°C	6.30 kW	5.50 kW
COP Tj = +2°C	4.34	3.22
Pdh Tj = +7°C	4.10 kW	3.50 kW
COP Tj = +7°C	5.51	4.61
Pdh Tj = 12°C	4.80 kW	5.00 kW
COP Tj = 12°C	6.96	6.25
Pdh Tj = Tbiv	10.20 kW	9.20 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



2.89	1.90
9.30 kW	8.10 kW
2.66	1.92
0.97	0.98
65 °C	65 °C
2 W	2 W
20 W	15 W
15 W	15 W
35 W	35 W
electricity	electricity
2.20 kW	1.90 kW
5482 kWh	6136 kWh
	9.30 kW  2.66  0.97  65 °C  2 W  20 W  15 W  35 W  electricity  2.20 kW

Domestic Hot Water (DHW)

CEN heat pump KEYMARK





EN 16147		
Declared load profile	XL	
Efficiency ηDHW	98 %	
СОР	2.32	
Heating up time	1:00 h:min	
Standby power input	85.0 W	
Reference hot water temperature	51.0 °C	
Mixed water at 40°C	230 I	