

Page 1 of 7

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### **Login**

Summary of	OERTLI MONO AWHP 11	Reg. No.	037-0045-20
Certificate Holder	,		
Name	BDR Thermea FR (OERTLI)		
Address	57 rue de la Gare	Zip	67580
City	Mertzwiller	Country	France
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	OERTLI MONO AWHP 11		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.3 kg		
Certification Date	30.01.2020		
Testing basis	HP Keymark scheme rules rev. no. 7		



# **Model: MONO AWHP 11 MR**

Configure model		
Model name	MONO AWHP 11 MR	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply 1x230V 50Hz		

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.47 kW	4.15 kW
СОР	4.54	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shatting on the heat transfer medium now	passeu
Complete power supply failure	passed
Defrost test	passed

### Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	174 %	135 %
Prated	10.00 kW	10.00 kW
SCOP	4.41	3.44
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	8.90 kW	9.00 kW
COP Tj = -7°C	3.17	1.99
Cdh Tj = -7 °C	0.995	0.997
Pdh Tj = +2°C	5.40 kW	5.70 kW
COP Tj = +2°C	4.23	3.30
Cdh Tj = +2 °C	0.988	0.991
Pdh Tj = +7°C	3.60 kW	4.70 kW
COP Tj = +7°C	5.33	4.86
Cdh Tj = +7 °C	0.978	0.984
Pdh Tj = 12°C	4.30 kW	4.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



COP Tj = 12°C	7.66	6.35
Cdh Tj = +12 °C	0.973	0.977
Pdh Tj = Tbiv	8.90 kW	9.00 kW
COP Tj = Tbiv	3.17	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.35 kW	8.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.87
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.970
WTOL	60 °C	60 °C
Poff	15 W	15 W
РТО	15 W	15 W
PSB	15 W	15 W
РСК	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.65 kW	1.58 kW
Annual energy consumption Qhe	4681 kWh	5998 kWh



# **Model: MONO AWHP 11 TR**

Configure model		
Model name	MONO AWHP 11 TR	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.47 kW	4.15 kW
СОР	4.54	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shatting on the heat transfer medium now	passeu
Complete power supply failure	passed
Defrost test	passed

### **Average Climate**



EN 12102-1				
	Low temperature	Medium temperature		
Sound power level outdoor	60 dB(A)	60 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
$\eta_{s}$	173 %	134 %	
Prated	10.00 kW	10.00 kW	
SCOP	4.40	3.44	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
Pdh Tj = -7°C	8.90 kW	9.00 kW	
COP Tj = -7°C	3.17	1.99	
Cdh Tj = -7 °C	0.992	0.995	
Pdh Tj = +2°C	5.40 kW	5.70 kW	
COP Tj = +2°C	4.23	3.29	
Cdh Tj = +2 °C	0.983	0.987	
Pdh Tj = +7°C	3.60 kW	4.70 kW	
COP Tj = +7°C	5.31	4.88	
Cdh Tj = +7 °C	0.968	0.977	
Pdh Tj = 12°C	4.30 kW	4.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textsc{Page}}\ 7$$  of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	7.66	6.35
Cdh Tj = +12 °C	0.961	0.966
Pdh Tj = Tbiv	8.90 kW	9.00 kW
COP Tj = Tbiv	3.17	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.35 kW	8.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.87
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.950	0.960
WTOL	60 °C	60 °C
Poff	22 W	22 W
РТО	22 W	22 W
PSB	22 W	22 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.65 kW	1.58 kW
Annual energy consumption Qhe	4693 kWh	6012 kWh