Basic component	Function	Figure
Interface modules and BaseUnit BU type M0 for redundant connection	The ET 200SP R1 system: • Use as redundant IO device on PROFINET IO • Connects the ET 200SP to the IO controller • Exchanges data with the I/O modules via the backplane bus.	