

GridGuard AI - Daily Transformer Health Report

Period: May 25, 2025 | Generated: 2026-09-26 08:43 UTC

Metric	Average Value	Maximum Value	Threshold Limit
Transformer Temp (°C)	66.7 °C	68.8 °C	65.0 °C
Vibration (mm/s)	2.04 mm/s	2.35 mm/s	2.0 mm/s
Load Current (A)	150.7 A	173.3 A	150.0 A
Ambient Temp (°C)	32.7 °C	35.5 °C	35.0 °C
Thermal Stress Index	0.78 (High)	0.85 (High)	0.67

System Maintenance Recommendations:

- Inspect cooling fan system and oil radiator heat exchange efficiency.
- Verify load balancing across primary phases during peak El Niño thermal windows.
- Schedule DGA (Dissolved Gas Analysis) oil sample test within 3 days.