

GridGuard AI - Monthly Thermal Stress Overview

Period: May 2025 | Generated: 2026-09-26 08:43 UTC

Metric	Average Value	Maximum Value	Threshold Limit
Transformer Temp (°C)	66.7 °C	68.8 °C	65.0 °C
Vibration (mm/s)	2.04 mm/s	2.35 mm/s	2.0 mm/s
Load Current (A)	150.7 A	173.3 A	150.0 A
Ambient Temp (°C)	32.7 °C	35.5 °C	35.0 °C
Thermal Stress Index	0.78 (High)	0.85 (High)	0.67

System Maintenance Recommendations:

1. Inspect cooling fan system and oil radiator heat exchange efficiency.
2. Verify load balancing across primary phases during peak El Niño thermal windows.
3. Schedule DGA (Dissolved Gas Analysis) oil sample test within 3 days.